

Inspection Note

Date: 24.03.2025

Venue: Jahangir Puri near electrical pump house & Jahangir Puri Metro Station to Mukarba Chowk.

Inspection By: The site inspected by me (Sh. V.N. Vibek, ADG) in the presence of CE (N), SE (NMC), EE (C), EE (E), AE (C), AE (E) along with JE (C) & JE (E)

Key Discussions and Decisions:

1. Jahangir Puri EE Block near pump house drain was filled with floating debris & silt. Instruction was given for cleaning the same by 1st week of April, 2025.
2. Drain of Pump House Road to be opened from near electrical pump house upto the three bay drains.
3. Desilting of both side drain from Jahangir Puri Metro Station to Mukarba Chowk on Mall Road Extension and covering of drain & chambers with repair work on both sides to be completed by mid-April, 2025. Instructions given for repairing and cleaning of bell mouth and chambers.
4. Desilting of drain from Mukarba Chowk to Bhalswa, presently handed over to DMRC, and also drain will be repaired by submitting estimate to higher office by the associated Sub Division.
5. Electrical pump house at EE Block, Jahangir Puri to be repaired by civil Building Division.
6. Possibility will be explored to connect the Jahangir Puri Drain to Flood Drain by constructing an underground drain through Mukarba Chowk Subway. Matter to be discussed with ADG(P) by 1st April, 2025.
7. All lifts near Prepaid Booth, FOB near Mukarba Chowk, Sanjay Enclave, Noori Masjid Gate were found non-operational. These are to be made functional by 1st week of April, 2025.
8. Almost all electrical fittings were found missing in Mukarba Chowk Subway. These are to be replaced with less costly fittings.

Adg
2/4/2025