

## राष्ट्रीय राजधानी क्षेत्र दिल्ली सरकार

## GOVT. OF NATIONAL CAPITAL TERRITORY OF DELHI

कार्यालय अधीक्षण अभियन्ता सी०बी०एम०सी० एम-22, लोक निर्माण विभाग, द्वितीय तल, दिल्ली सचिवालय, नई दिल्ली-110002 फोन नं० 23392194	Office of the Superintending Engineer CBM Circle M-22, PWD, Level-2, Delhi Sachivalaya, New Delhi-2 Fax no. 23392191
--	--

सं० 23(क्यू.सी./लो०नि०वि०/सि०भ०अनु०परि०एम-22/ 712 दिनांक 24/03/14

सेवा में,

मुख्य अभियन्ता,  
भवन अनुरक्षण अंचल एम - 2,  
लो.नि.वि., एम.एस.ओ. भवन,  
तृतीय तल, नई दिल्ली।

विषय: अधीक्षण अभियन्ता, परिमंडल एम-22 द्वारा किये गए निरीक्षणों का ब्यौरा।

संदर्भ: सचिव (लो.नि.वि.) का पत्र सं. PS PWD/119-128 दिनांक 04.03.2014

क्र. सं.	दिनांक	विवरण	टिप्पणी
1	18/03/14	Inspection of 20 Nos. SPS Type Additional Class Rooms at GGSSS, Saboli, Delhi	The directions were given to field staff for (a) Progress of works should be monitored. (b) Single piece of kota stone should be used for staircase steps. (c) Material as per approved list should be allowed. (d) Primer coat should be done on the R.S. Joist.
2	19/03/14	A/R & M/O to Delhi Sachivalaya Building, I.G. Stadium Complex, New Delhi dg. 2013-14 (SH: Texture painting of external surface)	The directions were given to field staff for (a) The surface should be made smooth by POP birla putty wherever required before painting. (b) 43 bags of 25 Kg. of Asian paints, fine tex were found at agency's store. The genuineness of this should be checked. (c) The material should be brought at site in bulk (in advance). The conditions for this should also be incorporated in N.I.T.
3	20/03/14	Inspection of SPS Type Women Wing at I.T.I. Nand Nagari, Delhi	The D.C. (North - East) has desired that ground floor and two rooms at 1 <sup>st</sup> floor should be finished for election purpose before 31/03/2014.
4	21/03/14	Inspection of 13 Nos. SPS Type A.C.R. at New Seelampur, Delhi	The Executive Engineer (E) was asked to get complete the cabling work within a week's time so that internal finishing / painting work can be taken up.

स्लेट  
24/3/14  
अधीक्षण अभियन्ता

सि.भ.अनु.परि.एम-22, लो.नि.वि.,  
दिल्ली सचिवालय, नई दिल्ली

प्रतिलिपि:-

- कार्यपालक अभियन्ता, लो.नि.वि. मं. एम-221, दिल्ली सचिवालय, नई दिल्ली।
- कार्यपालक अभियन्ता, लो.नि.वि. मं. एम - 222, मानसरोवर पार्क, शाहदरा, दिल्ली।
- कार्यपालक अभियन्ता (वै.), लो.नि.वि. वै. मं. एम-251, एम.एस.ओ. भवन, चौथा तल, नई दिल्ली।  
(इस कार्यालय का पत्र सं. 23(विविध)/Vol-II/सि.भ.अनु.परि. एम-22/575 दिनांक 05.03.14 के अनुक्रम में रिपोर्ट इस कार्यालय को प्रेषित करें।) फ्र 1. 6. 24.

स्लेट  
24/3/14  
अधीक्षण अभियन्ता