

कार्यालय मुख्य अभियंता
भवन परियोजना अंचल बी-2
लो0नि0वि0 (दिल्ली सरकार)
दूसरा तल, एम.एस.ओ. भवन
आई.पी. एस्टेट, नई दिल्ली -2
दूरभाष-23319153,23724394
फैक्स-23324794



O/o Chief Engineer
Building Project Zone B-2
PWD (Govt. of NCT of Delhi)
2nd Floor, MSO Building
I.P. Estate, New Delhi - 2
Ph.:23319153, 23724394
Fax:23324794
E-mail: cepwddelhibpz2@gmail.com

**INSPECTION REPORT OF SARVAGYA KR. SRIVASTAVA, CHIEF
ENGINEER IN RESPECT OF BUILDING PROJECT ZONE, B-2**

DATED 22.4.2014

Attended the inspection and meeting to review the functioning of GTB hospital by Hon'ble LG, Delhi. Entire campus was spruced up by PWD by completing running works, removing malba and landscaping the entire unpaved area.

Newly constructed Diabetic Centre has been completed including landscaping of the surrounding area except for the provision of a fire curtain in front of the lifts at ground floor and a partition in front of the back door as desired by Delhi Fire Service for issuing Fire Clearance Certificate. Action should be taken by PM, B-22 and B-24 to hand over the building immediately to the hospital administration.

Hon'ble LG directed that action should be expedited for installing Medical Gas Pipeline in newly constructed 500-bedded hospital. The finish of the building also needs to be improved as four lower floors of the building have been lying closed for the last more than two years as it had been used only as stores.

Estimate for air-conditioning of top four floors, already under use, has been submitted by PWD. PM, B-22 to take immediate action for completion of finishing works in the hospital and hand over the building formally to the hospital administration along with electrical inventories and fittings in consultation with PM, B-24. PM, B-24 should expedite appointment of consultant for installation of MGPL in consultation with MS, GTB hospital.

**(Sarvagya Kr. Srivastava)
Chief Engineer (B-2)**

Email to:

1. PM, B-22
2. PM, B-24