


**PROJECT MANAGER
FLYOVER PROJECT CIRCLE F-13
PUBLIC WORKS DEPARTMENT, GOVT. OF DELHI
MUKARBA CHOWK, G. T. KARNAL ROAD,
DELHI - 110033**

Ph: 011-27691871, Fax No.: 011-27691971

E-Mail: pmpwddelhif13@gmail.com



F. No. 23(24-I)/PM/FPC/F-13/PWD/2014/

Date: - 30/5/14

Inspection Note

Sub: - Inspection Note for the work of "Comprehensive Development of Corridor (Outer Ring Road) between Mangolpuri to Madhuban Chowk".

Inspected the site of Mangolpuri to Madhuban Chowk along with EE, F-134 & Mr. Kalra, DPM of M/s. ITD today i.e. on 30.05.2014. The segment of first span A-1_P-1 have been erected but gluing and temporary pre-stressing has not been completed due to inadequate arrangement at site.

Drainage work at A-1_P-1 was in progress and EE was directed to complete the same by 10th June' 2014. Shuttering of one pier (P- 28) was almost completed and reinforcement for shear key was to be placed. Piling near Deepali Chowk was in progress and top reinforcement cage was reviewed and found to be O.K. EE was directed to work out the program of spine casting with Mr. Venkat of M/s. ITD and discuss the same with undersigned by Monday.

Cleaning of old & new drain was in progress and it was directed to connect newly constructed drain with the road on priority. At most of the places, malba from the footpath has been removed and the same has been dressed nicely. This will provide a smooth surface to Pedestrians. The efforts of EE, F-134, in this regard, is appreciated. He should ensure that at no place, malba should be left in the stretch.

30/5
O/c Project Manager
Flyover Project Circle F-13, PWD

Copy to:-

- (1) Chief Engineer, Flyover Project Zone F-1, PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Executive Engineer, FPD, F-134 for information & necessary action please.
- (3-5) The Executive Engineer, FPD, F-131, F-132 & F-133. They should also ensure that all the old drains should be desilted and new drains connected with the road on top priority as already directed on number of occasions. The footpath should be nicely dressed after removing of malba, as done in the stretch from Mangolpuri to Madhuban Chowk.

30/5
O/c Project Manager