

कार्यालय मुख्य अभियंता
भवन परियोजना अंचल बी-2
लो0नि0वि0 (दिल्ली सरकार)
दूसरा तल, एम.एस.ओ. भवन
आई.पी. एस्टेट, नई दिल्ली -2
दूरभाष-23319153,23724394
फैक्स-23324794



O/o Chief Engineer
Building Project Zone B-2
PWD (Govt. of NCT of Delhi)
2nd Floor, MSO Building
I.P. Estate, New Delhi - 2
Ph.:23319153, 23724394
Fax:23324794
E-mail: cepwddelhibpzb2@gmail.com

**INSPECTION REPORT OF SARVAGYA KR. SRIVASTAVA, CHIEF
ENGINEER IN RESPECT OF BUILDING PROJECT ZONE, B-2**

DATED 30.5.2014

Visited Maulana Azad Institute of Dental Sciences (MAIDS) and held discussion with the Director, MAIDS regarding renovation of toilets, regular maintenance and testing of fire alarm and firefighting system and C/o new building.

PM, B-24 to ensure that no area should be left without fire extinguishers while these are taken for refilling which should be done without loss of much time. He should also ensure that periodic testing of fire alarm and sprinkler system is carried out. The Director and other officers of MAIDS may be informed and test should preferably be conducted in their presence to build confidence.

**(Sarvagya Kr. Srivastava)
Chief Engineer (B-2)**

Email to:

PM, B-24