अधीक्षण अभियन्ता परिमंडल एम 24 लोक निर्माण विभाग दिल्ली यमुना का अनुप्रवाह पश्चिमी तटबंध लोक नायक सेतु, आई.टी.ओ. नई दिल्ली 110 002 द्रभाष 011-23378275, 011-23378274 (के.)



SUPERINTENDING ENGINEER
CIRCLE M-24
PUBLIC WORK DEPARTMENT, GNCTD
DOWN STREAM WESTERN YAMUNA BANK
LOK NAYAK SETU I.T.O.
NEW DELHI -110 002

PH: 011-23378275, 011-23378274 (FAX)

e:mall pwdm24@gmail.com & sepwddelhim24@pwddelhi.com

## निरीक्षण नोट

विषयः Construction of Foot over Bridge with staircase and lifts for pedestrians across road NH 24 near at Samaspur Bus Stop, Delhi. SH: Civil Work.

करार सं. 50/EE M-212/2013-14 ऐजेन्सी M/s PMS Builtech Pvt. Ltd.

The above mentioned work was inspected by the undersigned on **29.04.2014** and the following points were noted:-

- The work is abnormally delayed. Contractor should deploy extra resources to complete the work expeditiously.
- 2. Programme for balance work should be obtained from contractor and a copy submitted to this office.
- 3. As per the earlier revised programme submitted by the contractor, the work was scheduled to be completed by 15.06.2014. However, various activities are behind the schedule by two to three weeks time. Executive Engineer should obtain another revised programme from the contractor in which the completion date should remain as 15.06.2014, but extra resources should be deployed and other activities be reverse integrated to complete the work by that date.
- As heavy structural members are being fabricating by welding, adequate testing facilities for welding should be available at site and welding work should be thoroughly checked.
- 5. Executive Engineer PWD M-212 to liaison with Executive Engineer M-253 and traffic police on urgent basis so that excavation work in central verge can be immediately started.

6. Back filling soil is to be properly compacted and watered.

एस के रामपाल अधीक्षण अभियन्ता परिमंडल एम 24

ग्रिमंडल ग्रिक

सं-/No. 12(1)परिमण्डल/एम 24/लोनिवि/ 🤇 🤻 🥇

दिनांक/Date: -04-2014

सेवा मे,

कार्यपालक अभियन्ता, एम 212, लोनिवि, दिल्ली