

अधीक्षण अभियन्ता
परिमंडल एम 24
लोक निर्माण विभाग दिल्ली
यमुना का अनुप्रवाह पश्चिमी तटबंध
लोक नायक सेतु, आई.टी.ओ.
नई दिल्ली 110 002
दूरभाष 011-23378275, 011-23378274 (फै.)



SUPERINTENDING ENGINEER
CIRCLE M-24
PUBLIC WORK DEPARTMENT, GNCTD
DOWN STREAM WESTERN YAMUNA BANK
LOK NAYAK SETU I.T.O.
NEW DELHI -110 002
PH: 011-23378275, 011-23378274 (FAX)
e.mail pwdm24@gmail.com & sepwddelhim24@pwwdelhi.com

निरीक्षण नोट

विषय: Improvement of Patparganj underpass including drainage slip road and carriageway over the underpass of NH-24, Delhi.

करार सं. 09/EE/PWD/M-212/2013-14

एजेन्सी M/s Gupta Construction Co.

The above mentioned work was inspected by the undersigned on **28.04.2014** and the following points were noted:-

1. The work is abnormally delayed. Contractor should deploy extra resources to complete the work expeditiously.
2. Programme for balance work should be obtained from contractor and a copy submitted to this office.
3. The work on the approach road from underpass to Ghaziabad bound carriageway is still incomplete. Stone pitching, toe wall, bollard fixing and malba removal etc. are still pending.
4. In the underpass portion, the condition of bituminous macadam is very pathetic. Potholes have appeared at many places which should be repaired.
5. Laying of pipeline in the underpass portion is still not complete on both sides, including cover slabs and manhole covers.
6. Executive Engineer should liaison with forest department for early approval of tree cutting permission so that retaining wall work can be expedited.

(Handwritten signature)

एस के रामपाल
अधीक्षण अभियन्ता
परिमंडल एम 24

जा०५१७०

सं./No. 12(1)परिमंडल/एम 24/लोनवि/ 871

दिनांक/Date: 30 -04-2014

सेवा में,

कार्यपालक अभियन्ता,
एम 212, लोनवि, दिल्ली