


कार्यालय मुख्य अभियंता
भवन परियोजना अंचल बी-2
लो0नि0वि0 (दिल्ली सरकार)
दूसरा तल, एम.एस.ओ. भवन
आई.पी. एस्टेट, नई दिल्ली -2
दूरभाष-23319153,23724394
फैक्स-23324794



O/o Chief Engineer
Building Project Zone B-2
PWD (Govt. of NCT of Delhi)
2nd Floor, MSO Building
I.P. Estate, New Delhi - 2
Ph.:23319153, 23724394
Fax:23324794
E-mail: cepwddelhibpz2@gmail.com

**INSPECTION REPORT OF SARVAGYA KR. SRIVASTAVA, CHIEF
ENGINEER IN RESPECT OF BUILDING PROJECT ZONE, B-2**

DATED 09.7.2014

Held a meeting in the camp office at LNJP hospital with PM, B-23 & B-24 and other officers responsible for operations and maintenance of infrastructure and services in MAMC and all other allied hospitals. There has been complaint of AC not functioning at most of the places. In fact, the OT of GNEC had to be shut down because of infection which could have been caused due to rise in temperature because of non-functioning of the ACs. Simultaneously there have been complaints about civil works in toilets and other areas not being attended in time. The PMs were instructed to immediately put in place the system of lodging of complaint and its quick disposal as had been decided earlier. The Executive Engineers responsible for maintenance of ACs were instructed to get all the ACs installed under their jurisdiction listed in the register showing their location, year of installation and present position, whether working satisfactory or not within next two days. Subsequently, similar operation should be carried out for all dessert coolers also.

All the Executive Engineers were instructed to personally inspect the areas under their control and ensure that complete cleanliness is maintained particularly in their offices, stores and sub-stations where lot of dismantled material and garbage keeps lying for a long time. All the toilets and common facilities should be kept in working condition.

**(Sarvagya Kr. Srivastva)
Chief Engineer
BPZ B-2**

Email to :

1. PM, B-23
2. PM, B-24