


**PROJECT MANAGER  
FLYOVER PROJECT CIRCLE F-13  
PUBLIC WORKS DEPARTMENT, GOVT. OF DELHI  
MUKARBA CHOWK, G. T. KARNAL ROAD,  
DELHI - 110033**

Ph: 011-27691871, Fax No.: 011-27691971

E-Mail: [pmpwddelhif13@gmail.com](mailto:pmpwddelhif13@gmail.com)



F. No. 23(28-I)/PM/FPC/F-13/PWD/2014/ 1800

Date: - 31-7-14

**Inspection Note**

**Sub: - Inspection Note for the work of "Comprehensive Development of Corridor (Outer Ring Road) between Madhuban Chowk to Mukarba Chowk."**

Inspected the site of Madhuban Chowk to Mukarba Chowk along with Mr. Kharia, P.M. of M/s. ITD & EE, F-131 today i.e. on 31.07.2014. First went to the location of ED Block, where drainage pipeline work has almost been completed except few manholes. It was also directed to do neat cement punning on inside plaster of manhole.

Then went to the location of A-1 side where there was some confusion w.r.t. the drainage work. EE was directed to submit the details of drain levels with respect to various outfall points. It was also pointed out that drain should be located towards service road so that there is no problem in future widening of main carriage way. This has already been pointed out earlier on number of occasions. It was also directed that drain work on L.H.S. should be completed on priority. Police help may be taken if local people creates some hindrance to the work.

Then went on the deck of the P-3, P-4 span where pre-stressing work was in progress. Mr. Ganeshan of M/s. LTR also joined and he was shown some minor surface cracks in few segments. He was requested to suggest the remedial measures for these surface cracks.

EE, F-131 was also directed to take up the matter with M/s. CRRRI officials for deploying required number of Engineers at site. It is felt that EE should have taken necessary action in this regard much earlier.

  
Project Manager  
Flyover Project Circle F-13, PWD

**Copy to:-**

- (1) Chief Engineer, Flyover Project Zone F-1, PWD, 12<sup>th</sup> Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Executive Engineer, FPD, F-131 for information & necessary action please.

  
Project Manager