

Thereafter, again went to the Libaspur casting yard where self-compacting concrete prepared through batching plant was ready for pouring after 2 hours retention time. When the concrete was poured, the flow was O.K. but concrete bled. This type of concrete is not acceptable and Quality In-charge of M/s. CEC and EE, F-133 was directed to do more trail mixes to ensure that cohesive concrete mixes prepared with retention time of 2 hours.

de 4/8

Project Manager
Flyover Project Circle F-13, PWD

Copy to:-

- (1) Chief Engineer, Flyover Project Zone F-1, PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Executive Engineer, FPD, F-133 for information & necessary action please.

de 4/8

Project Manager