

कार्यालय मुख्य अभियंता
भवन परियोजना अंचल बी-2
लो0नि0वि0 (दिल्ली सरकार)
दूसरा तल, एम.एस.ओ. भवन
आई.पी. एस्टेट, नई दिल्ली -2
दूरभाष-23319153, 23724394
फैक्स-23324794



O/o Chief Engineer
Building Project Zone B-2
PWD (Govt. of NCT of Delhi)
2nd Floor, MSO Building
I.P. Estate, New Delhi - 2
Ph.: 23319153, 23724394
Fax: 23324794
E-mail: cepwddelhibpz2@gmail.com

**INSPECTION REPORT OF SARVAGYA KR. SRIVASTAVA, CHIEF
ENGINEER IN RESPECT OF BUILDING PROJECT ZONE, B-2**

DATED 08.8.2014

Inspected GB Pant hospital complex and held meeting with Director and other medical officers of the hospital.

Proposal for new building to be constructed is to be finalized immediately for seeking in principle approval of Govt. of Delhi for construction of the same.

It was reported that chlorination at few places was not being done properly due to which contamination was detected in the water supply at few locations. PM, B-24 to look into the matter and ensure proper chlorination and simultaneously take action for automation of entire water supply scheme including online chlorination at the earliest to avoid human failures in such matters.

Sanction has been given by hospital administration for renovation of OT on the 5th Floor for which tenders both for civil as well as electrical works should be called immediately to start the work at the earliest.

It was reported that the ETP was not functioning properly. PM, B-24 to look into the matter and submit a report immediately after taking necessary action.

(Sarvagya Kr. Srivastva)
Chief Engineer
BPZ B-2

Email to:

1. PM, B-23
2. PM, B-24