

कार्यालय अधीक्षण अभियंता
सिविल भवन अनुरक्षण परिमंडल,
एम-43, लोक निर्माण विभाग,
11वां तल, एम.एस.ओ. भवन,
लोक निर्माण विभाग मुख्यालय,
नई दिल्ली-110002
दूरभाष: 65103943, 23490488



O/o THE SUPERINTENDING ENGINEER
CIVIL BUILDING MAINTENANCE CIRCLE, M-43,
PUBLIC WORKS DEPARTMENT
11th Floor, MSO Building, PWD Headquarter,
NEW DELHI- 110002
PHONE : 65103943, 23490488
Email: sepwddelhim43@gmail.com

INSPECTION NOTE

The following work of Sarva Shiksha Abhiyan was inspected by the undersigned on 21-08-2014 along with Sh. A.K.Singh, Executive Engineer, M-433 and Sh. R.P.Verma, Assistant Engineer, M-4333 and representative of the contractor (M/s Varun Singla Construction).

Name of work: Construction of 14 Nos. ACR, 3 Nos. Toilets & 13 Nos. Ramps for DoE Schools Civil Works SSA (Central & New Delhi District) (SH: C/o 5 Nos. ACR, 2 Nos. Girls Toilets & 11 Nos. Ramps).

Agreement No. : 35/EE/CBMD M-433/2014-15
Estimated Cost : Rs. 92,07,149/-
Tendered Amount : Rs. 77,79,120/-
Date of Start : 13-07-2014
Date of Completion : 12-01-2015

The following observations have been made:-

- The work has recently been started and brick work up to lintel level for 5 Nos. additional class rooms at Plot No.-6, Jhandewalan, Karol Bagh completed.
- Some caution boards (i.e. Men at work), Small barricading etc. may be provided around construction site to avoid entry of the students in the area.
- The instructions were issued to put the date on wall so as to observe curing period.
- EE has to ensure that RCC Bands are provided in brick work as per standard practice for masonry building/load bearing masonry structure.
- It must be ensured that barrier free access is provided with ramps.
- Conduit for Electrical works must be provided simultaneously for better finishing.

- Since work is to be carried out in other schools also, this should be taken up simultaneously to complete the work earliest in all schools.
- The Efforts should be made to complete the work before stipulated period i.e. within next 3 months to avoid inconvenience to the students and school authority and make available additional facility for the schools.

(एस0 के0 अग्रवाल)
अधीक्षण अभियन्ता


संख्या: 23(204)/सि0भ0अनु0परि.एम-43/लोनिवि/2014-15/ 1624

दिनांक: 25 अगस्त 2014

प्रतिलिपि:

- ✓ 1. मुख्य अभियन्ता, अनुरक्षण अंचल, एम-4, लो.नि.वि., 9वां तल, एम.एस.ओ. भवन, नई दिल्ली को सूचनार्थ।
2. कार्यपालक अभियन्ता, एम-433, लो.नि.वि., नई दिल्ली को सूचनार्थ एवं उपरोक्त बिन्दुओं पर कार्रवाई कर शीघ्र अनुपालन रिपोर्ट प्रस्तुत करने हेतु।
3. गार्ड फाईल।

अधीक्षण अभियन्ता


22/8/14