




दिल्ली सरकार
कार्यालय, कार्यपालक अभियन्ता
लोक निर्माण विभाग, मंडल एम-423
सुखदेव विहार, नई दिल्ली।
दूरभाष: 26928300, फ़ैक्स: 26928301
E-mail ID : eepwddelhim423@gmail.com



GOVT. OF DELHI
OFFICE OF THE EXECUTIVE ENGINEER
PUBLIC WORKS DEPARTMENT DIVISION M-423
SUKHDEV VIHAR, NEW DELHI.
PHONE: 26928300, FAX: 26928301
E-mail ID : eepwddelhim423@gmail.com

सं०

23()/सि.भ.अनु.मं.एम-423/डी.बी./14-15/ 1836

दिनांक: 18/09/14


INSPECTION NOTE

The Labour Welfare Building at Kalkaji, Giri Nagar was inspected on 17.09.2014 by the Underground alongwith Sh. Dalip Singh, AE-M-4231, Sh. Sunil Kataria, JE, M-4231 and the concerned contractor. The following observation have been made:-

1. Name of work : Renovation of Labour Welfare Centre, Giri Nagar, Kalkaji, New Delhi, New Delhi during 2013-14 (SH: C/o SPS Type Cafeteria Block Store Room & 1 Toilet Block).
Agreement No. : 101/EE/M-423/2013-14
Name of Contractor : Sh. Rajesh Yadav
Tendered Amount : 27,63,087/-
Date of Start : 13.03.2014
Date of completion : 12.07.2014

- (i) The work is at advance stage of completion.
- (ii) At few locations of verandah, joints were not properly finished, hence required to be rectified.
- (iii) At few locations, sand stone fixed in the roof have been found undulated, which are required to be corrected. The filling of joints at some locations are not done properly. It requires to be done properly.
- (iv) At some locations, finishing of kota stone flooring is not proper which requires to be properly done.
- (v) Distemping and painting work on doors left the spot on walls need to be cleaned properly.
- (vi) The painting work on doors have some irregular patches which requires to be done properly.

The Assistant Engineer, M-4231 is directed to take immediate necessary action and get the above defects rectified and complete the balance work by the end of this month since the work is already running in extended time period.


Executive Engineer
CBMD M-423, PWD,

Copy to:

1. The Superintending Engineer, CBMC, M-42, PWD, Sukhdev Vihar, New Delhi for information please.
2. AE, M-4231, PWD, Giri Nagar, Nagar, New Delhi for information and necessary compliance report be submitted within a week.


Executive Engineer