




**PROJECT MANAGER
FLYOVER PROJECT CIRCLE F-13
PUBLIC WORKS DEPARTMENT, GOVT. OF DELHI
MUKARBA CHOWK, G. T. KARNAL ROAD,
DELHI - 110033**

**Ph: 011-27691871, Fax No.: 011-27691971
E-Mail: pmpwddelhif13@gmail.com**



F. No. 23(28-I)/PM/FPC/F-13/PWD/2014/ 2560

Date: - 22-10-14

Inspection Note

Sub: - Inspection Note for the work of "Comprehensive Development of Corridor (Outer Ring Road) between Madhuban Chowk to Mukarba Chowk."

Inspected the site of Madhuban Chowk to Mukarba Chowk on 22.10.2014 along with EE, F-131 and DPM of M/s. ITD. First, inspected the span where longitudinal stitching of wings with spine segments in first span have been completed. The wing erection in second span was in progress. EE was directed to personally check the alignment of these wings after following the methodology circulated by undersigned. It was directed that simultaneous checking of alignment of wings along with its erection is very much necessary to point out the deficiencies at right time and also to maintain the progress of work. It is not appreciated that all the wing segments have been erected in this span still EE has not checked the alignment as according to undersigned, few wings need to be brought closer to the spine segments. During my earlier inspection, it was pointed out that before erection of wings, the concrete surface should be properly cleaned and hacked but the same has not been followed in this case also.

It is once again stressed that to have quality work in an expeditious manner, advance action w.r.t. checking of slopes of side face of spine and vertical fins of wing segments, cleaning and hacking of concrete surface should be done so that erection is completed expeditiously and desired quality is achieved.

Then, visited the site of Haryana Canal where slab of bridge on L.H.S. has been casted yesterday. EE was directed to ensure proper curing of the same.


Project Manager
Flyover Project Circle F-13, PWD

Copy to:-

- (1) Chief Engineer, Flyover Project Zone F-1, PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Executive Engineer, FPD, F-131 for information & necessary action please.
- (3-4) The Executive Engineer, FPD, F-132 and F-134 for necessary action as mentioned above.


Project Manager