


**PROJECT MANAGER
FLYOVER PROJECT CIRCLE F-13
PUBLIC WORKS DEPARTMENT, GOVT. OF DELHI
MUKARBA CHOWK, G. T. KARNAL ROAD,
DELHI - 110033**

Ph: 011-27691871, Fax No.: 011-27691971

E-Mail: pmpwddelhif13@gmail.com



F. No. 23(28-I)/PM/FPC/F-13/PWD/2014/3048

Date: - 23/12/14

Inspection Note

Sub: - Inspection Note for the work of "Comprehensive Development of Corridor (Outer Ring Road) between Madhuban Chowk to Mukarba Chowk."

Inspected the site of Madhuban Chowk to Mukarba Chowk on 23.12.2014 along with Executive Engineer, F-131 & Project Manager of M/s. ITD Cementation. It was informed that ten wing spans have been erected and work of erection of wings in three spans is in progress.

During inspection it was pointed out that while erection, levels should be properly checked by PWD Engineers as well as Engineers of the Contractor before allowing stitch concrete. At one location the levels of one wing segment were checked and certain corrections were required to be made.

The RE wall work on A-1 side was also in progress and it was informed that the same will be completed by Jan.' 2015.

Then, went to the location of Haryana Canal where RC wall work is going on very slow. It was again emphasized that since Bridge deck slab has already been casted, the c/o approach should be completed on top most priority so that movement of traffic through widened Bridge is allowed for smoother execution of work.

Also went to the Mukarba Chhowk ROB where RE wall work is going on very slow. The progress of these critical items was also reviewed in the O/o undersigned with EE, F-131 and Project Manager of M/s. ITD. The agency informed that they will complete the ramps of Haryana Canal by the end of Jan.' 2015.

The work of casting of crash barriers of ramp should also be expedited so that the widening of ROB is not affected.

[Signature]
Project Manager

Flyover Project Circle F-13, PWD

Copy to:-

- (1) Chief Engineer, Flyover Project Zone F-1, PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Executive Engineer, FPD, F-131 for information & necessary action please.

[Signature]
Project Manager