



**PROJECT MANAGER  
FLYOVER PROJECT CIRCLE F-13  
PUBLIC WORKS DEPARTMENT, GOVT. OF DELHI  
MUKARBA CHOWK, G. T. KARNAL ROAD,  
DELHI - 110033**

**Ph: 011-27691871, Fax No.: 011-27691971**

**E-Mail: [pmpwddelhif13@gmail.com](mailto:pmpwddelhif13@gmail.com)**



F. No. 23(29-I)/PM/FPC/F-13/PWD/2015/

690

Date: - 8-4-15

**Inspection Note**

**Sub: - Inspection Note for the work of "Comprehensive Development of Corridor (Outer Ring Road) between Vikaspuri to Meerabagh."**

Inspected the site of Vikaspuri to Meerabagh Project along with EE, F-132 and Project Manager of M/s. Simplex on 02.04.2015. First, inspected the work going on in nallah portion where work of pile caps, piers, pier cap on both sides of existing bridge were going on but sufficient labour was not deployed. It was directed to deploy separate teams for taking up various activities simultaneously so that work of pile caps, piers, pier caps etc. is completed before onset of monsoon. The Executive Engineer was also directed to get the detailed program of execution of work in nallah portion and discussed with undersigned as this is one of the most critical activity.

Then, went to A-1 ramp and had a meeting with Mr. Naseem Akhtar of M/s. CRRI to discuss the arrangement of fixing of noise barriers. Various options were discussed and certain suggestions were made. Mr. Naseem Akhtar was requested to explore the possibility of implementation of suggestions made during the meeting and discuss the same on 08.04.2015.

Then, went to CRPF Red light where the Executive Engineer discussed various issues pertaining to c/o footpath and toe wall. The issue of providing tuck tile for footpath was also discussed in detail. EE was directed to study whether guide tuck tiles are required or not as per prevalent practice. The EE was also directed to ensure that kerb stones are properly fixed with minimum joint thickness and proper groove.

7/4/15

**O/c Project Manager  
Flyover Project Circle F-13, PWD**

**Copy to:-**

- (1) Chief Engineer, Flyover Project Zone F-1, PWD, 12<sup>th</sup> Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Executive Engineers, FPD, F-132 for information & necessary action please.

7/4/15

**O/c Project Manager**