



**PROJECT MANAGER  
FLYOVER PROJECT CIRCLE F-13  
PUBLIC WORKS DEPARTMENT, GOVT. OF DELHI  
MUKARBA CHOWK, G. T. KARNAL ROAD,  
DELHI - 110033**

**Ph: 011-27691871, Fax No.: 011-27691971**

**E-Mail: [pmpwddelhif13@gmail.com](mailto:pmpwddelhif13@gmail.com)**



F. No. 23(28-I)/PM/FPC/F-13/PWD/2015/ 740

Date: - 22-4-15

**Inspection Note**

**Sub: - Inspection Note for the work of "Comprehensive Development of Corridor (Outer Ring Road) between Madhuban Chowk to Mukarba Chowk."**

Inspected the site of Madhuban Chowk to Mukarba Chowk on 21.04.2015 along with EE, F-131 & Project Manager of M/s. ITD Cementation.

Went to the site of ED Block on R.H.S. adjacent to Madhuban Chowk underpass. The widening of road is held up for small issues. After discussion, the agency was directed that this part of road widening should be completed within next 10 days. There is a dhalao on R.H.S. coming in ROW of PWD for which MCD has demanded around 20 lacs of rupees. The EE, F-131 proposed that MCD has also given an option that PWD may also construct a new dhalao at site shown by MCD officials which will be a cheaper option. The proposal of the EE was agreed upon.

The issue of drain on R.H.S. between ED Block and Power House was also discussed. It was suggested that in the present site conditions, possibility of providing pipe drain with manholes at 15 mtrs. Centre to centre, may be explored.

The status of finishing of underdeck was enquired and it was intimated that the same has not been started by the agency till date. This is a time consuming job and undersigned has been stressing this issue for a long time but it is regretted to point out that no serious action has been taken till date. The EE, F-131 & Project Manager of M/s. ITD both were directed to ensure that this activity is started on top priority.

*[Signature]*  
o/c Project Manager

**Flyover Project Circle F-13, PWD**

**Copy to:-**

- (1) Chief Engineer, Flyover Project Zone F-1, PWD, 12<sup>th</sup> Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Executive Engineer, FPD, F-131 for information & necessary action please.

*[Signature]*  
o/c Project Manager