


PROJECT MANAGER FLYOVER PROJECT CIRCLE F–13 PUBLIC WORKS DEPARTMENT, GOVT. OF DELHI MUKARBACHOWK, G. T. KARNAL ROAD, DELHI – 110033

Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: pmpwddelhif13@gmail.com

F. No. 23(23) (I)/PM/FPC/F-13/PWD/2015/ 1/28



Date: - 28-5-15

Inspection Note

Name of work: -

Comprehensive Development of Corridor (Outer Ring Road) between Mukarba Chowk to WazirabadChowk.

Inspected the site of Mukarba Chowk to Wazirabad along with EE, F-133 and Project Manager of M/s. CEC on 26.05.2015.

First, went to the location of Bhalswa Bridge where erection of RCC beam was in progress. The detailing of its erection, placing of bearings and its grouting was discussed in detail. Certain modifications in the shutter around bearing for grouting purpose were proposed. It was suggested that thicker wooden batons may be used for this purpose.

Then, went to the site of Burari flyover where steel girders of RHS were being assembled at ground. The EE was directed to check the certain details like length of nut & bolts and edge distance of hole in splice plates as per specifications. The erection methodology was also discussed in detail and it was directed that, the erection of steel girder on RHS should be completed by 20th June and deck slab casting should be completed by 30th July' maximum. Similarly, the programme for L.H.S. carriageway should also be prepared.

Then, went to the Jagatpur flyover where piling work around 220 KVA line was in progress. It was advised to take full precautions while doing the piling work in this area to avoid any accident.

Then, went to the Bhalswa Chowk Flyover location where PCC for RE wall, adjacent to drain on L.H.S. (A-1 ramp side) was in progress. It was directed to ensure the proper curing of the PCC and maintain its line & level. The new drain has been made functional and it was directed that the work of widening of A-1 and Λ -2 side on L.H.S. of Bhalswa Flyover should be taken up in full swing.

Project Manager /)
Flyover Project Circle F-13, PWD

Copy to:-

(1) Pr. Chief Engineer, Flyover Project Zone F-1, PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.

(2) The Executive Engineer, FPD, F-133 for information & necessary action please.

de Project Manager