

PROJECT MANAGER FLYOVER PROJECT CIRCLE F-13 PUBLIC WORKS DEPARTMENT, GOVT. OF DELHI MUKARBACHOWK, G. T. KARNAL ROAD, **DELHI-110033**

Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: pmpwddelhif13@gmail.com

F. No. 23(23) (I)/PM/FPC/F-13/PWD/2015/



Date: -

Inspection Note

Comprehensive Development of Corridor (Outer Ring Road) between Name of work: -Mukarba Chowk to WazirabadChowk.

Inspected the site of Mukarba Chowk to Wazirabad along with EE, F-133 and Project Manager of M/s. CEC on 04.07.2015.

Started the inspection from Libaspur drain. Then, went to the Bhalswa, loop-1 and loop-2 to review the status of clearing of water ways. Lot of clearing has been done and it was directed to clear the balance water way as per the targets committed during Pr. Secy., PWD's site visit on 28th June' 2015.

Then, went to the Jagatpur flyover location and reviewed the status of installation of bearings where orientation of the pedestal has been changed. It was found that the reinforcement for the pedestal is not proper and needs correction. It was also directed that EE, F-132 or his AEs and Engineers of the agency should properly check the reinforcement of pedestals before allowing installation of bearings.

Then, reviewed the status of fabrication of girders of various flyovers. It was noticed that the progress of fabrication is not satisfactory at all. It was noticed that agency is not ensuring the timely supply of steel plates to the fabricator and also not pursing the progress of fabrication. Fabrication of steel girders and its erection has become very critical and should be monitored very closely. The status of road widening was also reviewed which is also going on very slow.

The Project Manager of M/s. CEC was directed to submit the detailed program of fabrication and erection of steel girder and road widening immediately. Next review meeting is on 06/08/2015 in the chamber of Pr. Chief Engineer, FPZ F-1, PWD.

> Project Manager Flyover Project Circle F-13, PWD

Pr. Chief Engineer, FPZ F-1, PWD, 12th Floor, MSO Building, New Delhi for kind information (1)

The Executive Engineer, FPD, F-133 for information & necessary action please. (2)