
	CHIEF PROJECT MANAGER (FLYOVER) 1 PUBLIC WORKS DEPARTMENT GOVT. OF DELHI MUKARBA CHOWK, G. T. KARNAL ROAD, DELHI - 110033 Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: cpmpwddelhif1@gmail.com	
---	--	---

F. No. 23(23) (I)/CPM/F 1/PWD/2015/

2150

Date: 23-9-15

Inspection Note

Name of work: - Comprehensive Development of Corridor (Outer Ring Road) between Mukarba Chowk to Wazirabad Chowk.

Inspected the site of Jagatpur flyover along with EE, F-133 and DPMs of M/s. CEC on 23.09.2015.

Reviewed the reinforcement of box girder between P-10 to P-13 and reinforcement of blister which was in progress. The details of pouring was also discussed in the light of discussion held yesterday with Mr. P.G.V. It was advised that the concreting should be done in two pours and first pour should be done up to top of bottom blister and in the second pour concrete of balance portion of web and deck slab should be done. The time between the first pour and second pour should be minimized to the maximum extent possible. Before allowing the concrete of first pour i.e. bottom slab and part of web, all arrangement including shuttering, scaffolding, reinforcement bars, as per BBS of deck slab should be ready so that the gap between the first pour and second pour is minimized.

Then, went to the site of Burari flyover where preparation for deck slab casting on R.H.S. was being made. On the L.H.S., two span's main girder are still to be erected. The EE informed that they are targeting to complete the erection within this week. The status of road widening on A-1 side, L.H.S. at Burari was enquired which is not going on as per the last discussion. The EE was directed to vigorously pursue the matter with the agency to ensure that the Burari flyover is opened to the traffic by 31st Dec.' 2015 as committed to the Delhi Govt.

23/9
O/c Chief Project Manager
(Flyover) 1, PWD

Copy to:-

- (1) The E-in-C (Projects), PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The OSD (PWD) to Minister, O/o of the Minister, Power, PWD, Health, Industries & Home, GNCTD, A-Wing, 7th Level, Delhi Secretariat, I.P. Extension, New Delhi-110002 for kind information please.
- (3) The Executive Engineer, FPD, F-133 for information & necessary action please.

23/9
O/c Chief Project Manager