

CHIEF PROJECT MANAGER (FLYOVER) 1 PUBLIC WORKS DEPARTMENT

PUBLIC WORKS DEPARTMENT GOVT. OF DELHI

MUKARBA CHOWK, G. T. KARNAL ROAD, DELHI – 110033

Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: cpmpwddelhif1@gmail.com



F. No. 23(24-I)/ CPM/F 1/PWD/2015/

2380

Date: - 19-10-15

Inspection Note

Sub: - Inspection Note for the work of "Comprehensive Development of Corridor (Outer Ring Road) between Mangolpuri to Madhuban Chowk".

Inspected the site of Mangolpuri to Madhuban Chowk along with the PM, F-15 and Project Manager of M/s. ITD Cementation on 17.10.2015.

The DBM layer was in progress over the APP layer on LHS. The PM, F-15 was directed to ensure that proper compaction and level of DBM layer should be ensured. It was also suggested to provide a kerb channel along the central verge so as to channelize the water through pipes provided for drainage from one side of the carriageway to other side of the carriageway.

Then, took the round of whole site. It was directed to start the repair work in the crash barrier/central verge in a time bound manner, wherever required, and the same should be closely monitored span-by-span.

The other activities of under deck finishing, sample of anti-carbonation paint as approved by E-in-Chief, PWD, provisions of rain water pipes below deck surface, the work of footpath, drain etc.should also be taken up in full swing.

d. Chief Project Manager (Flyover) 1, PWD

Copy to:-

(1) The E-in-Chief (Projects), PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.

(2) The Pr. Chief Engineer (Projects), PWD, 9th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.

The OSD (PWD) to Minister, O/o of the Minister, Power, PWD, Health, Industries & Home, GNCTD, A-Wing, 7th Level, Delhi Secretariat, I.P. Extension, New Delhi-110002 for kind information please.

(4) The Project Manager, F-15, PWD for information and n.a. please.

Chief Project Manager