

	<p align="center">CHIEF PROJECT MANAGER (FLYOVER) 1 PUBLIC WORKS DEPARTMENT GOVT. OF DELHI MUKARBA CHOWK, G. T. KARNAL ROAD, DELHI - 110033</p> <hr/> <p align="center">Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: cpmpwddelhif1@gmail.com</p>	 <p align="center">एक कदम स्वच्छता की ओर</p>
---	--	---

F. No. 23(23) (I)/CPM/F 1/PWD/2015/

192

Date: 22-1-16

Inspection Note


Name of work: - Comprehensive Development of Corridor (Outer Ring Road) between Mukarba Chowk to Wazirabad Chowk.

Inspected the site of Burari flyover along with EE, F-11, PWD and Project Manager of M/s. CEC on 21.01.2016.

The work of WMM on A-1 ramp was in progress. It was directed to deploy more number of grinders to do the necessary rectification in crash barrier and central verge wherever required. Installation of expansion joint should also be expedited and utmost care should be taken to ensure proper levelling of concrete with the adjoining bituminous surface while laying the expansion joints. The work of nose protection at the start of A-1 and A-2 ramp should also be started immediately. Before painting of crash barrier and central verge, all the pin-holes should be properly filled up. All other activities including installation of street lights should be expedited so as to ensure that this elevated corridor is completed before 31st Jan.' 2016.


Inspected the site of Libaspur Bridge along with EE, F-11, PWD and concerned DPM of M/s. CEC on 22.01.2016.

Inspected the Libaspur Bridge and finalised the profile of approach to the Bridge on A-1 and A-2 side. Certain rectification in central verge are required and it was directed to dismantle that much of central verge and recast. While fixing the shutter for crash barrier, reinforcement should be checked properly. It was also directed to expedite the various activities so as to complete the same by 31st Jan.' 2016.


 Chief Project Manager
 (Flyover) 1, PWD

Copy to:-

- (1) The E-in-C (Projects), PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Pr. Chief Engineer (Projects), PWD, 9th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (3) The OSD (PWD) to Minister, O/o of the Minister, Power, PWD, Health, Industries & Home, GNCTD, A-Wing, 7th Level, Delhi Secretariat, I.P. Extension, New Delhi-110002 for kind information please.
- (4) The Executive Engineer, F-11, PWD for information & necessary action please.


 Chief Project Manager