

	<p align="center"><b>CHIEF PROJECT MANAGER (FLYOVER) 1 PUBLIC WORKS DEPARTMENT GOVT. OF DELHI MUKARBA CHOWK, G. T. KARNAL ROAD, DELHI - 110033</b></p> <p align="center">Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: <a href="mailto:cpmpwddelhif1@gmail.com">cpmpwddelhif1@gmail.com</a></p>	
--	---	---

F. No. 23(28-I)/CPM/F 1/PWD/2016/

९६०


Date: - 19-4-16

Inspection Note

**Sub: -** Inspection Note for the work of "Comprehensive Development of Corridor (Outer Ring Road) between Madhuban Chowk to Mukarba Chowk."


Inspected the site of Madhuban Chowk to Mukarba Chowk ~~on 08/04/2016~~ along with SE, F-14 and his AEs on 14.04.2016.

The fixing of rain water pipes below deck and footpath work being carried out on R.H.S. was reviewed. It was directed to ensure that while fixing the rain water pipes, dash fasteners are not inserted at the location of H.T. strands of wing/spine segments. Lot of observations were raised in the footpath work. It was directed to attain the perfect level of manhole cover with adjoining tiles as well as line and level of paver tiles should be maintained. While laying the paver tiles, proper compaction should be ensured.

 **Chief Project Manager**  
(Flyover) 1, PWD  
19/4

Copy to:-

- (1) The E-in-Chief, PWD, 12<sup>th</sup> Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Pr. Chief Engineer (Projects), PWD, 9<sup>th</sup> Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (3) The OSD (PWD) to Minister, O/o of the Minister, Power, PWD, Health, Industries & Home, GNCTD, A-Wing, 7<sup>th</sup> Level, Delhi Secretariat, I.P. Extension, New Delhi-110002 for kind information please.
- (4) The Superintending Engineer, F-14, PWD for information & necessary action please.

 **Chief Project Manager**  
19/4