

	<p align="center">CHIEF PROJECT MANAGER (FLYOVER) 1 PUBLIC WORKS DEPARTMENT GOVT. OF DELHI MUKARBA CHOWK, G. T. KARNAL ROAD, DELHI - 110033</p> <p>Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: cpmpwddelhif1@gmail.com</p>	
--	--	---

F. No. 23(28-I)/CPM/F 1/PWD/2016/1776

Date: - 8-7-16

Inspection Note

Sub: -Inspection Note for the work of "Comprehensive Development of Corridor (Outer Ring Road) between Madhuban Chowk to Mukarba Chowk."

Inspected the site of Madhuban Chowk to Mukarba Chowk along with AEs of F-14 and Project Manager of M/s. ITD Cementation on 06.07.2016.

One sample of colour scheme of anti-carbonation paint has been prepared in span A-1_P-1. It was advised to prepare 2-3 spans so that the real impact is felt.

Then, in the site office, reviewed the various pending items which are as below: -

- It was informed that malba is being cleaned regularly from the site and the same may be completed on priority.
- The rectification of footpath should be completed as per earlier directions on priority.
- For collection of rain water, manholes are to be constructed at number of locations and the same are to be connected to the rain water harvesting chambers.
- The end of the footpath should be sloped and bollards should be provided.
- The finishing of RE wall panels, crash barrier etc. should be completed before anti-carbonation paint is started.
- The works of signage is not being started which should be expedited.
- The work of street light poles at ground should also be completed on priority.
- The desilting of drain and clearing of bell mouth pipe should be ensured to avoid any flooding during rainy season.
- It was also directed to prepare the list of all the pending activities and should be got completed on priority.

9/7
Chief Project Manager
(Flyover) 1, PWD

Copy to:-

- (1) The E-in-Chief, PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Pr. Chief Engineer (Projects), PWD, 9th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (3) The OSD (PWD) to Minister, O/o of the Minister, Power, PWD, Health, Industries & Home, GNCTD, A-Wing, 7th Level, Delhi Secretariat, I.P. Extension, New Delhi-110002 for kind information please.
- (4) The Superintending Engineer, F-14, PWD for information & necessary action please.

9/7
Chief Project Manager