

	<p align="center"><b>CHIEF PROJECT MANAGER (FLYOVER) 1 PUBLIC WORKS DEPARTMENT GOVT. OF DELHI MUKARBA CHOWK, G. T. KARNAL ROAD, DELHI - 110033</b></p> <hr/> <p align="center"><b>Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: <a href="mailto:cpmpwddelhif1@gmail.com">cpmpwddelhif1@gmail.com</a></b></p>	 <p align="center">एक कदम स्वच्छता की ओर</p>
---	--	---

F. No. 23(23) (I)/CPM/F 1/PWD/2016/

1904

Date: 26-7-16

Inspection Note

**Name of work: - Comprehensive Development of Corridor (Outer Ring Road) between Mukarba Chowk to Wazirabad Chowk.**


Inspected the site of Mukarba Chowk to Wazirabad along with the EE, F-11 and the Project Manager of M/s. CEC today on 26.07.2016.

Went to Mukundpur flyover where road carpenting on R.H.S. deck slab was being started. It was directed to ensure proper levelling on both sides of expansion joint so that movement over expansion joints is jerk free.

Also, reviewed the progress of erection of girders and casting of deck slab on R.H.S. As on dated, the erection work was not going on in three spans due to non-payment to the labour by M/s. P&R. The matter was also discussed with M.D. of M/s. P&R to resolve the issue and complete the erection work on priority which has been delayed badly.


The progress of casting of crash barrier of deck slab and A-2 ramp on R.H.S. is far from satisfactory. Ideally, 50-60 mtr. crash barrier should be casted but it is felt that even 10 mtr. per day is not being casted. The Project Manager of M/s. CEC was directed to look into the issue and expedite the same.

Pot-holes, on L.H.S. adjacent to A-1 ramp of Mukundpur, have developed which should be filled up on priority. The EE, F-11 was directed to immediately call a meeting today in the chamber of the undersigned, with higher management of M/s. CEC.

  
 Chief Project Manager  
 (Flyover) 1, PWD

Copy to:-

- (1) The Engineer-in-Chief, PWD, 12<sup>th</sup> Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Pr. Chief Engineer (Projects), PWD, 9<sup>th</sup> Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (3) The OSD (PWD) to Minister, O/o of the Minister, Power, PWD, Health, Industries & Home, GNCTD, A-Wing, 7<sup>th</sup> Level, Delhi Secretariat, I.P. Extension, New Delhi-110002 for kind information please.
- (4) The Executive Engineer, F-11, PWD for information & necessary action please.

  
 Chief Project Manager