

	<p align="center"><b>CHIEF PROJECT MANAGER (FLYOVER) 1 PUBLIC WORKS DEPARTMENT GOVT. OF DELHI MUKARBA CHOWK, G. T. KARNAL ROAD, DELHI – 110033</b></p> <hr/> <p align="center"><b>Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: <a href="mailto:cpmpwddelhif1@gmail.com">cpmpwddelhif1@gmail.com</a></b></p>	 <p align="center">एक कदम स्वच्छता की ओर</p>
---	--	---

F. No. 23(23) (I)/CPM/F 1/PWD/2016/

2247

Date: 7.09.2016

**Inspection Note**

**Name of work: - Comprehensive Development of Corridor (Outer Ring Road) between Mukarba Chowk to Wazirabad Chowk.**

Inspected the site of Mukarba Chowk to Wazirabad alongwith EE/F-11 on 7.09.16. First went to Mukundpur flyover where casting of deck slab on RHS last module of 32-45 mtr. was in progress. It was directed to ensure proper cover at all locations by providing sufficient cover blocks. It was also directed to do proper curing of slab, already casted, by ponding.

It was also observed that in certain portion of crash barrier of LHS carriageway, line and level needs improvement. EE/F-11 was directed to ensure that some portion should be got dismantled and recasted. Wherever future casting of crash barrier is done, utmost care should be taken.

In certain portion of crash barrier, on back side, minor honey-combing was observed which should be repaired.

The progress of fixing of expansion joints on LHS carriageway is very slow and needs to be expedited.

Then went to Jagatpur flyover site. Reviewed the progress of work. NDPL has started shifting the NDPL lines from twin pole on the road going to Jagatpur. EE/F-11 was also directed to co-ordinate with NDPL authorities for start the shifting of NDPL lines in other area on priority. If required, NDPL poles may be fixed on drain walls as done for twin poles to expedite the shifting and necessary cost adjustment may be done with NDPL.

The C.E.C. should also expedite the road widening in this area so that ramp of the flyover is started.

It has been pointed out that electrical agency is delaying the street light work and it was directed to call a meeting in the chamber of undersigned on 2:00 PM on 7.09.2016.

7/9  
**Chief Project Manager  
(Flyover) 1, PWD**

**Copy to:-**

- (1) The Engineer-in-Chief, PWD, 12<sup>th</sup> Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Pr. Chief Engineer (Projects), PWD, 9<sup>th</sup> Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (3) The OSD (PWD) to Minister, O/o of the Minister, Power, PWD, Health, Industries & Home, GNCTD, A-Wing, 7<sup>th</sup> Level, Delhi Secretariat, I.P. Extension, New Delhi-110002 for kind information please.
- (4) The Executive Engineer, F-11, PWD for information & necessary action please.

7/9  
**Chief Project Manager**

o/c