

	<p style="text-align: center;"><b>CHIEF PROJECT MANAGER (FLYOVER) 1 PUBLIC WORKS DEPARTMENT GOVT. OF DELHI MUKARBA CHOWK, G. T. KARNAL ROAD, DELHI - 110033</b></p> <hr/> <p style="text-align: center;">Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: <a href="mailto:cpmpwddelhi1@gmail.com">cpmpwddelhi1@gmail.com</a></p>	 <p style="text-align: center;">एक कदम स्वच्छता की ओर</p>
---	---	--

F. No. 23(23)/CPM/F 1/PWD/2016/

2624


Date: 27 .10.2016

Inspection Note

**Name of work: -Comprehensive Development of Corridor (Outer Ring Road) between Mukarba Chowk to Wazirabad Chowk**

Inspected the site of Mukundpur flyover on 26,10,16 alongwith EE/F-11 and DPM of M/s. CEC. The fixing of expansion joint was in progress. EE/F-11 was directed to ensure that expansion joints are properly levelled with adjoining bituminous road surface so as to have jerk free movement over expansion joints. The activities of surface preparation of crash barrier, painting, fixing of rainwater spout etc. should also be taken up in full swing. The matter was also discussed with PM of M/s. CEC to enhance the various resources to complete the activities on Mukundpur flyover on priority. The planning should also be made to complete the balance BC work of ramps on RHS carriageway.

dc

  
**Chief Project Manager  
(Flyover) 1, PWD**

**Copy to:-**

- (1) The Engineer-in-Chief, PWD, 12<sup>th</sup> Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Pr. Chief Engineer (Projects), PWD, 9<sup>th</sup> Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (3) The OSD (PWD) to Minister, O/o of the Minister, Power, PWD, Health, Industries & Home, GNCTD, A-Wing, 7<sup>th</sup> Level, Delhi Secretariat, I.P. Extension, New Delhi-110002 for kind information please.
- (4) The Executive Engineer, F-11, PWD for information & necessary action please.

dc

  
**Chief Project Manager**