

	<p align="center">CHIEF PROJECT MANAGER (FLYOVER) 1 PUBLIC WORKS DEPARTMENT GOVT. OF DELHI MUKARBA CHOWK, G. T. KARNAL ROAD, DELHI – 110033</p> <hr/> <p align="center">Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: cpmpwddelhif1@gmail.com</p>	
---	--	---

F. No. 23(23 I)/CPM/F 1/PWD/2016/ 2928

Date: 7 .12.2016


Inspection Note

Name of work: - Comprehensive Development of Corridor (Outer Ring Road) between Mukarba Chowk to Wazirabad Chowk.

Inspected the site of Mukarba Chowk to Wazirabad on 07.12.16 with EE/F-11 and Project Manager of M/s. CEC. Went to the site of FOB-3 and reviewed the reinforcement of pile cap and pedestal of RH Side where it was in progress.


Certain issues with regard to the positioning of Macloy bar, pouring of concrete and its compaction etc. were discussed in details. There is a huge congestion of reinforcement in pedestal and proper compaction may be a issue. The issue of using of self compacting concrete in pedestal was also discussed. EE/F-11 was directed to discuss these issues with consultants for their suggestion. Proper template should be used to ensure proper positioning of Macloy bar and its angle. EE/F-11 was also directed to thoroughly check the reinforcement of pile cap, pedestal before allowing concreting.

Then, went to site of Jagatpur flyover and discussed the various issues of widening of road going towards Jagatpur. On left hand side, soil retaining structure is required to be constructed and EE/F-11 was directed to submit the suitable proposal for the same. On RHS, observed some new encroachment coming up and EE/F-11 was directed to take up the matter with concerned authorities to stop the encroachment. He was also advised to take up the matter with Irrigation & Flood Control Department for demarcation of right of way. The erection of steel girders in Jagatpur flyover needs to be expedited.

o/c 
**Chief Project Manager
(Flyover) 1, PWD**

Copy to:-

- (1) The Engineer-in-Chief, PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Pr. Chief Engineer (Projects), PWD, 9th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (3) The OSD (PWD) to Minister, O/o of the Minister, Power, PWD, Health, Industries & Home, GNCTD, A-Wing, 7th Level, Delhi Secretariat, I.P. Extension, New Delhi-110002 for kind information please.
- (4) The Executive Engineer, F-11, PWD for information & necessary action please.

o/c 
Chief Project Manager