

	<p style="text-align: center;">CHIEF PROJECT MANAGER (FLYOVER) 1 PUBLIC WORKS DEPARTMENT GOVT. OF DELHI MUKARBA CHOWK, G. T. KARNAL ROAD, DELHI - 110033</p> <hr/> <p style="text-align: center;">Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: cpmpwddelhi1@gmail.com</p>	
---	--	--

F. No. 23(23 I)/CPM/F 1/PWD/2017/ 129

Date: 13 .01.2017

Inspection Note

Name of work: - Comprehensive Development of Corridor (Outer Ring Road) between Mukarba Chowk to Wazirabad Chowk.

Inspected the site of Mukarba Chowk to Wazirabad on 13.01.16 with EE/F-11 and Project Manager of M/s. CEC. First went to Bhalswa bridge location, on parallel road side, where work is held up due to intercepter sewer well of DJB. EE/F-11 was advised to call a meeting with DJB officials at site to resolve the issue. Then, went to Mukundpur rotary, where rotary work was discussed in detail. It was also directed to complete the work of approach of loop-1 on priority.

Then, went to Jagatpur flyover and discussed the programme of various activities. The reinforcement of deck slab of one module, above rotary of parallel road, was almost ready. EE/F-11 was directed to thoroughly check the reinforcement before allowing concreting. Arrangement of rain water spouts was also discussed in the area where location is coming on the steel girder. It was decided to provide rain water spouts within crash barrier. The agency was also directed to expedite the casting of box girder in the nallah portion.

Status of other activities like stone pitching, cycle track, footpath & green belt etc. was also enquired. The agency committed that they are trying to complete 3 KM stretch within this month in all respect. The programme of various activities was also discussed in the chamber of undersigned. It was noticed that the programme brought for discussion was not updated. Project Manager of CEC was directed to keep the programme updated and monitor the same on daily basis.

ok

13/1/17
Chief Project Manager
(Flyover) 1, PWD

Copy to:-

- (1) The Engineer-in-Chief, PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Pr. Chief Engineer (Projects), PWD, 9th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (3) The OSD (PWD) to Minister, O/o of the Minister, Power, PWD, Health, Industries & Home, GNCTD, A-Wing, 7th Level, Delhi Secretariat, I.P. Extension, New Delhi-110002 for kind information please.
- (4) The Executive Engineer, F-11, PWD for information & necessary action please.

ok

13/1/17
Chief Project Manager