

	<p align="center">CHIEF PROJECT MANAGER (FLYOVER) 1 PUBLIC WORKS DEPARTMENT GOVT. OF DELHI MUKARBA CHOWK, G. T. KARNAL ROAD, DELHI – 110033</p> <hr/> <p align="center">Ph: 011-27691871, Fax No.: 011-27691971 E-Mail: cpmpwddelhi1@gmail.com</p>	
---	--	--

F. No. 23(23 I)/CPM/F 1/PWD/2016/ **280**

Date: **30** .1.2017


Inspection Note

Name of work: - Comprehensive Development of Corridor (Outer Ring Road) between Mukarba Chowk to Wazirabad Chowk.

Inspected the site of Mukarba Chowk to Wazirabad on 28.01.17 with EE/F-11 and Project Manager of M/s. CEC.


First went to the site of loop -1 where part erection of steel box girder was already completed and next part erection was planned on 29.01.2017. Thereafter went to the location of loop 2 where also part erection was planned on 29.1.17. Also inspected the steel box girders lying at the site. Following are the observations:-

1. It was noticed that inside the box girders, at few locations, painting has not been done properly due to presence of stiffener plates. EE/F-11 was directed to ensure that all the box girders are properly painted.
2. Before erection of steel girders, proper cleaning from inside should be ensured.
3. In the supporting cribs, it was noticed that some bolts are missing on the junction of cribs. This aspect may be checked thoroughly at all the places and needful be done on priority.
4. Where the girders have been erected, it was directed to provide side guard , welded on cribs, to avoid any toppling of girder due to any mis-happening.
5. It was also directed to anchor the cribs with road surface .
6. During the round of site on 30.01,17. It was observed that at few locations concrete Jersey barrier should be placed near the cribs to avoid any direct hitting by fast moving vehicles during any accident.


**Chief Project Manager
(Flyover) 1, PWD**

Copy to:-

- (1) The Engineer-in-Chief, PWD, 12th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (2) The Pr. Chief Engineer (Projects), PWD, 9th Floor, MSO Building, I.P. Estate, New Delhi for kind information please.
- (3) The OSD (PWD) to Minister, O/o of the Minister, Power, PWD, Health, Industries & Home, GNCTD, A-Wing, 7th Level, Delhi Secretariat, I.P. Extension, New Delhi-110002 for kind information please.
- (4) The Executive Engineer, F-11, PWD for information & necessary action please.


Chief Project Manager