


कार्यालय प्रधान मुख्य अभियंता (अनुरक्षण)
लोक निर्माण विभाग,
राष्ट्रीय राजधानी क्षेत्र (दिल्ली सरकार)
9वां तल, एम.एस.ओ. भवन,
नई दिल्ली- 110002
दूरभाष : 23319795/ फ़ैक्स: 23317728



O/o THE PR. CHIEF ENGINEER (Maintenance)
PUBLIC WORKS DEPARTMENT, GNCTD,
9TH FLOOR, M.S.O.BUILDING
I.P. ESTATE, NEW DELHI- 110002
Phone: 23319795 Fax: 23317728
Email id : prceprojectspwddelhi@gmail.com

No. 61(1)/PR.CE(Maint.)/PWD/2017/274

Date: - 01/03/2017


INSPECTION NOTE

An inspection of roads was carried out by Pr. CE (M), PWD on 18/02/2017 in which Chief Engineer (East)-M, Superintending Engineer (East), Superintending Engineer (C&ND) alongwith all Executive Engineers from Civil & Electrical wing and officials from Horticulture wing of East Zone were present.

During the inspection Pr. CE (M) made following observations:

1. The footpath and central verge should be repaired on regular basis and should be kept neat and clean.
2. Maintenance van should be equipped with required T&P and materials & GPS system. The workers should be in proper uniform. The field staff should monitor the activity of maintenance van on daily basis, so that it is properly and effectively utilized.
3. The bell mouths should be cleaned and cleared so that they function effectively during the rainy season.
4. Regular watering of plants & removal of garbage / rubbish from green areas should be carried-out.
5. Proper lane marking and signages at required places should be installed and maintained.
6. Pot holes / patch repair where ^{रखी} required to be attended on priority.
7. Undersigned desires to witness the Benkelman Beam Test when carried out in future.
8. The operation of vacuum cleaning machine was inspected on Vikas Marg over Yamuna river bridge portion. It may be ensured that the operation of the machine be regularly supervised so as to get effective output from it.


1.3.2017
(A.K. GARG)


Pr. Chief Engineer (Maintenance)
PWD (GNCTD)

Copy to :-

1. The C.E. (East), PWD (GNCTD), 3rd Floor, MSO Building, I.P. Estate, New Delhi.
2. The SE (C&ND), PWD (GNCTD), T. Junction, Ring Road, Near Pragati Power Station, New Delhi 110002.
3. The S.E.(East), P.WD (GNCTD), Players Building, Delhi Sachivalya, New Delhi 02.
4. PS to Pr. Chief Engineer (M).


Director (M)

11/3/2017