

अधीक्षण अभियन्ता  
केन्द्रीय एवं नई दिल्ली परिमंडल  
लोक निर्माण विभाग,  
राष्ट्रीय राजधानी क्षेत्र, दिल्ली सरकार,  
भैंरो मार्ग टी-जंक्शन, रिंग रोड,  
नियर प्रगति पावर स्टेशन,  
नई दिल्ली-110002  
फोन नं.-23378613/14



E-mail ID :sepwddelhicnd@gmail.com

Superintending Engineer  
Central & New Delhi Circle  
Public Works Department  
Govt. of NCT of Delhi,  
Bhairon Marg T-Junction, Ring  
Road,  
Near Pragati Power Station,  
New Delhi-110002  
Phone No.: 23378613 / 14

No.: 23(15)/Inspection of work/SE/C&ND/PWD/2017-18/ 3434 Date: 27-07-2017

### Inspection Note

Following works were inspected in presence of Sh. Rajiv Khare, AE and Contractor representative on 22.07.2017 and directions given for compliance:-

#### 1) Construction of FOB at Sindhora Kalan –

- i) Progress of work is slow. Sh. Gaurav, Contractor's site Engineer mentioned that work shall be completed by 20.08.2017. Contractor to give completion schedule in this regard.
- ii) AE (E) requested for provision of a room for the purpose of panel board and operator rest room. EE, C&ND Road to take necessary action.
- iii) Lift should be provided with lock and key.

#### 2) Accessibility work being executed on the footpath at University Campus –

- i) Steel railing provided are not slanting and are fixed at a distance from the start of ramp. This is rejected. Proper railing should be provided as per convenience to differently abled persons and proper ramp should be provided to footpath for the smooth passage of wheel chair.
- ii) Welding of railing is not proper, it may be rectified. Finishing are not smooth.
- iii) Dotted tectile tile should be provided whenever there is change of direction/hindrance. The tectile tile should be continued throughout the footpath without any abrupt end.
- iv) Joints are not properly finished in red sand stone being provided at footpath.
- v) It should be ensured that approved brand of tectile tile is used at site.

अधीक्षण अभियन्ता

केन्द्रीय एवं नई दिल्ली परिमंडल (एम0)

Copy to-

1. The CE East (M), PWD, 3<sup>rd</sup> Floor, MSO Building, IP Estate, New Delhi-110002.
2. The EE (C&ND) Road, PWD, Bhairon Marg T-Junction, Ring Road, New Delhi-110002 – for compliance and ATR by 04/08/2017.
3. The EE (E), C&ND Electrical (M-351), Old Secretariat, Delhi for necessary action.
4. Guard file.

अधीक्षण अभियन्ता