By Hand/Speed Post/E-Mail

अधीक्षण अभियन्ता
केन्द्रीय एवं नई दिल्ली परिमंडल
लोक निर्माण विभाग,
राष्ट्रीय राजधानी क्षेत्र, दिल्ली सरकार,
भैरो मार्ग टी-जंकशन, रिंग रोड,
नियर प्रगति पावर स्टेशन,
नई दिल्ली-110002
फोन न:- 23378613 / 14



E-Mail ID: sepwddelhicnd@gmail.com

Superintending Engineer
Central & New Delhi Circle
Public Work Department
Govt. of NCT of Delhi,
Bhairon Marg T-Junction, Ring Road,
Near Pragati Power Station,
New Delhi – 110002
Fax No.:- 23379693

सं0: 23(15)/Inspection of Work/SE/C&ND/PWD/2017-18/

दिनांक:14 / 08 / 2017

## **INSPECTION NOTE**

Inspection of various work under (C&ND) Road Division was carried out by SE (C&ND)-M along with EE (C&ND)-R and AE incharge of work on 11/08/2017. During the inspection, following directions were given for compliance: -

- 1. Repair of footpath at Ring Road near VikasMinar.
- Repair/Painting of dwarf wall, repair of steps with kota near Y-Shape Building on Service Road of Ring Road.
- 3. Repair of Tactiles, Granite Stone flooring, Manhole cover, drain cover, Ceramic Tiles flooring, Steel cover on Gully Chamber on I.P. Marg.
- 4. Stainless steel railing at Tilak Bridge drain and between Tilak Bridge and Ram Charan Aggarwal Chowk may be provided. The existing M.S. railing on central verge near Tilak Bridge may be shifted to BSZ, Mathura Road wherever it is missing.
- 5. Repair of planters, footpath, central verge etc. on Bahadur Shah Zafar Marg.
- 6. Repair of footpath, island, kerb stone, carriage way etc. on JLN Marg.
- Camber correction to improve riding surface on I.P. Marg near Institute of Engineer Building.
- 8. Repair of footpath, drain on Sachivalaya Road, loops of I.P. Marg.
- 9. Repair of footpath and drain near I.P. Subway.

The direction may be complied urgently and ATR be submitted within 2 weeks.

अधीक्षण अभियन्ता केन्द्रीय एवं नई दिल्ली (एम०)

प्रतिलिपि प्रेषित:-

1. मुख्य अभियन्ता, ईस्ट (एम), लो.नि.वि., तीसरा तल, एम.एस.ओ. भवन, नई दिल्ली-110002

2. कार्यपालक अभियन्ता, लो.नि.वि., के.एवं.न.दि. रोड़ मंडल (एम-413), भैरों मार्ग टी-जंक्शन, नई दिल्ली-110002- for compliance.

3. रांo: 23(81)/Road/SE/C&ND/PWD/2017-18

4. गार्ड फाईल।

de अधीक्षण अभियन्ता