

<p>अधीक्षण अभियन्ता केन्द्रीय एवं नई दिल्ली परिमंडल लोक निर्माण विभाग, राष्ट्रीय राजधानी क्षेत्र, दिल्ली सरकार, भैंसो रोड टी-जंक्शन, रिंग रोड, नियर प्रगति पावर स्टेशन, नई दिल्ली-110002 फोन नं.-23378613/14</p>	 <b>E-mail ID :sepwddelhicnd@gmail.com</b>	<p><b>Superintending Engineer</b> Central &amp; New Delhi Circle Public Works Department Govt. of NCT of Delhi, Bhairon Road T-Junction, Ring Road, Near Pragati Power Station, New Delhi-110002 <b>Phone No.: 23378613 / 14</b></p>
--	--	--

No. 23(15)/SE/C&amp;ND/PWD/2017-18/

3898

Date: 28-08-2017

**INSPECTION NOTE**

Following works were inspected on 26.08.2017 along with EE, AE, JE & representative of contractor. Officers from Civil and Electrical both were present:-

**1) C/o Additional space for HCM Camp Office**

- i. Iron Frame for window AC to be painted properly with matching wall surface.
- ii. Gaps below door chowkat be filled with Silicon gel.
- iii. The scratch/mark on the wall surface be removed.
- iv. Toilet fittings are of varied brand. Needs to be of one brand.
- v. Extension of roof near main entry is needed for proper sun and rain cover.
- vi. Unwanted angle valves may be removed from wash room.

**2) C/o of DDC Office at 33 Sham Nath Marg**

- i. Granite colour should be matching in the corridor.
- ii. Gutter at terrace needs to be cleaned.
- iii. Water tank platform needs repair.
- iv. Polish of Granite at edge is not proper.
- v. Rest block to rain water pipe be provided.
- vi. Bib cock in pantry should be long body.
- vii. All joints of tiles(floor/wall) should be filled properly and cleaned.
- viii. No water should be stagnated outside the building.
- ix. DDH is requested to provide green cover in the kaccha portion of new DDC Building on urgent basis.

EEs/DDH are requested to rectify the above defects and compliance report be submitted by 01.09.2017.

अधीक्षण अभियन्ता  
केन्द्रीय एवं नई दिल्ली परिमंडल (एम0)

**प्रतिलिपि प्रेषित:-**

- 1- The CE (East) M, PWD, New Delhi-110002 for information please.
- 2- The OSD to Minister, PWD, 7<sup>th</sup> Floor, A-Wing I.P Sectt., New Delhi-110002.
- 3- The EE, C&ND Bldg. Divn.(M-323), C&ND Elect. Divn. (M-351), DHC&ND/Central Elect. Divn. (M-451) & DDH Divn.(M-214) PWD, Delhi for immediate action and compliance report by 01.09.2017.
- 4- No. 23(99,91)/SE/C&ND/PWD/2017-18
- 5- Guard file.

अधीक्षण अभियन्ता