

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>अधीक्षण अभियन्ता केन्द्रीय एवं नई दिल्ली परिमंडल लोक निर्माण विभाग, राष्ट्रीय राजधानी क्षेत्र, दिल्ली सरकार, भैंसो मार्ग टी-जंक्शन, रिंग रोड, नियर प्रगति पावर स्टेशन, नई दिल्ली-110002 फोन नं.-23378613/14</p> | <p></p> <p></p> <p>E-mail ID : sepwddelhicnd@gmail.com</p> | <p>Superintending Engineer Central & New Delhi Circle Public Works Department Govt. of NCT of Delhi, Bhairon Marg T-Junction, Ring Road, Near Pragati Power Station, New Delhi-110002 Phone No.: 23378613 / 14</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

सं० : 23(15)/SE/C&ND/PWD/2017-18/ 4098

दिनांक : 12.09.2017

Inspection Note

Ms. Abha Negi, Accessibility Consultant visited University Campus roads on 06.09.2017 relating to road accessibility and safety. During the inspection, following directions were given :

1. Tactile should be provided in continuity. Linear tactile should be provided along the straight path involving no change in direction. Dotted tactile should be provided whenever there is change in direction.
2. Pruning should be done where trees / plants are obstructing the path, sign board etc.
3. Footpath at the entrance of College / Institution should be raised for maintaining the level of adjoining footpath by providing ramp (1:10) and drainage pipes. For providing table top on the main carriageway the slope of ramp can be 1:8.
4. Cover slab to manhole should be at the matching level of footpath.
5. Sign board should be provided after 1 feet from the footpath edge towards carriageway. Height of sign board should be more than 8 feet from the ground.
6. For the informatory sign board, Ms. Abha Negi suggested for cantilever bigger sign board for the convenience of public.
7. Red sand stones kerb stones provided at University Road should be painted black & white for clear visibility.
8. Zebra crossing, lane marking, speed calming measures, delineators, solar studs etc. should be provided.
9. Proper nosing should be provided where the road bifurcate.
10. A sample stretch is to be developed incorporating the above features within 20 days.
11. At the visit to FOB, Sindhora Kalan, Ms. Abha Negi suggested the following :
 - a) Flamed granite may be used in place of polished granite.
 - b) It would be better if nose of different colours is used in the step or groove at nosing may be provided with different colour for identification of steps.
 - c) Tactile (Guide & Warning) to be provided at the landing and deck slab as discussed at site.
 - d) Railing at lower level is also to be provided at stair case and deck slab for the convenience of children and specially abled persons.
 - e) Lift should be provided with facility to visually and hearing impaired person.

प्रतिलिपि प्रेषित:-

1. मुख्य अभियन्ता, ईस्ट (एम), लो.नि.वि., तृतीय तल, एम0एस0ओ0 भवन, नई दिल्ली-110002
2. ओ.एस.डी., माननीय मुख्यमंत्री, दिल्ली सरकार, लो.नि.वि., 7वां तल, ए-विंग, दिल्ली सचिवालय, नई दिल्ली
3. कार्यपालक अभियन्ता, लो.नि.वि., केन्द्रीय एवं नई दिल्ली सड़क मंडल (एम-413), भैरों मार्ग टी-जंक्शन, रिंग रोड़, नियर प्रगति पावर स्टेशन, नई दिल्ली-110002 - He is to take action as mentioned above and submit ATR by 18.09.2017
4. कार्यपालक अभियन्ता (वै0), केन्द्रीय एवं नई दिल्ली वैद्युत मंडल (एम 351), लो.नि.वि., कमरा नं.-185, पुराना सचिवालय, दिल्ली-110054
5. The Dy. Director Hort. Divn. (M 214), G.S. Mihar Bhoaj Vatika., NH-24, Nizamuddin Bridge, New Delhi, 110091 - for pruning action.
6. गार्ड फाईल/23(81)/23(55)

o/c अधीक्षण अभियन्ता