

<p>अधीक्षण अभियन्ता के. ए. एवं नई दिल्ली परिमंडल लोक निर्माण विभाग, राष्ट्रीय राजधानी क्षेत्र, दिल्ली सरकार, मैसो रोड टी-जंक्शन, रिंग रोड, नियर प्रगति पावर स्टेशन, नई दिल्ली-110002 फोन नं.-23378613/14</p>	<p></p> <p></p> <p>E-mail ID :sepwddelhicnd@gmail.com</p>	<p><b>Superintending Engineer</b> Central &amp; New Delhi Circle Public Works Department Govt. of NCT of Delhi, Bhairon Road T-Junction, Ring Road, Near Pragati Power Station, New Delhi-110002 <b>Phone No.: 23378613 / 14</b></p>
--	---	--

No. 23(15)/SE/C&ND/PWD/2017-18/ 1208

Date: 22-03-2018

### Inspection Note

Various works under C&ND Road were inspected on 20.03.2018 by undersign along with Sh. Vinod Garg, AE, field staff and representative of the contractor. During the inspection, following observations were made:-

**A) Strengthening of Ring Road between Nigam Bodh Ghat to Metcalf House Xing under Sub-Division-3 of Division C & ND – Roads.**

Agreement No. : 79/EE/C&ND-R/M-413/PWD/2017-18  
Agency : M/s Winner Construction Pvt. Ltd.

- 1) In the DBM Work, rough patches are observed near ISBT and U-turn. This may be repaired immediately.
- 2) Density and thickness was checked for DBM near Shahadra loop, ISBT Kashmere Gate at 2 locations. Thickness of DBM found is 62 mm and 63 mm. Density of DBM found is 2.27 gm/cc and 2.28 gm/cc on these locations.
- 3) Samples of DBM should be sent to CDO for Bitumen extraction test and gradation test.

**B) Widening of Road including Subway near Nigam Bodh Ghat, Kashmere Gate, New Delhi.**

Agreement No. : 35/EE/C&ND-R/M-413/PWD/2017-18  
Agency : M/s SS Chauhan & Sons.

- 1) In the existing subway granite tile should be repaired and proper finishing should be done to the subway.
- 2) EE (E) Division M-451 to check proper lighting in the subway.
- 3) SFRC drain cover should be provided in the drain of existing Nigam Bodh Ghat Subway.
- 4) Epoxy painting of overhead sign board Gentry should be carried out.
- 5) It was observed that additional lane for the traffic and subway has been opened to public.
- 6) It was told by the contractor that tree cutting permission has been obtained. EE to ensure that trees are removed at the earliest and proper ramp to the subway be constructed urgently for the convenience of public.
- 7) The work is getting late and should be completed latest by 06.04.2018.



C) Improvement of Shantivan intersection due to Black Spot declared by Delhi Traffic Police for the Year – 2015 being Accidental Prone Area under Sub-Division-3 and Division C & ND-Roads, New Delhi (Civil Work).

Agreement No. : 206/EE/C&ND-R/M-413/PWD/2017-18  
Agency : M/s Basau Construction (India)

- 1) The work is stopped at the site due to leakage of unfiltered water pipe line. EE to ensure that leakage is attended urgently and work should be started at the earliest.
- 2) If the contractor do not start the work within a week, action should be taken against him for delay in completion of work.

D) Painting of Hanuman Setu on Ring Road with Anti-carbonation paint Sub-Division-3 of Division C & ND – Roads.

Agreement No. : 117/EE/C&ND-R/M-413/PWD/2017-18  
Agency : M/s Basau Construction (India)

- 1) Anti carbonation paint of Hanuman Setu should be completed by 22.03.2018 towards mandir side.
- 2) Malba should be removed under the Hanuman Setu parking area.
- 3) While painting, repair to concrete should be done simultaneously for providing smooth finish.
- 4) Repair to brick work for planter should be carried out simultaneously.
- 5) The work executed should be of top quality as Hon'ble LG regularly visit this area.
- 6) OSD to Hon'ble Minister, PWD has instructed to carry out desilting near Hanuman Mandir as Hanuman Jayanti is to be celebrated on 31.03.2018. EE to take necessary action in this regard.

E) Improvement of area below IP Metro Statio – Chair link fencing should be provided on both side of road so that people do not throw garbage in the drain.

(मुकेश कुमार)  
अधीक्षण अभियन्ता

प्रतिलिपि प्रेषित:-

1. The CE (East), PWD, 3<sup>rd</sup> floor, MSO Bldg., New Delhi-110002.
2. The EE, C&ND (M-413), PWD, Bhairon Road T-Jn., Ring Road, New Delhi-110002 – For compliance.
3. The EE, (DHC/ND) Elect. Divn. (M-451), PWD, Ground Floor, MSO Bldg., Delhi-110054 - for action on (B)-2 – For compliance.
4. The DDH Divn. (M-214), PWD, G.S. Mihar Bhoaj Vatika, NH-24, Nizamuddin Bridge, New Delhi-110091 - for action on (B)-6 – For compliance.
5. The ADH, PWD, Horticulture Sub-Div. East-2, Ground Floor, MSO Bldg., New Delhi for action on (B)-6 – For compliance.
6. Guard file.

अधीक्षण अभियन्ता