## अधीक्षण अभियन्ता

केन्द्रीय एवं नई दिल्ली परिमंडल लोक निर्माण विभाग, राष्ट्रीय राजधानी क्षेत्र, दिल्ली सरकार, भैंरो रोड टी—जंकशन, रिंग रोड, नियर प्रगति पावर स्टेशन, नई दिल्ली—110002 फोन न;—23378613 ∕ 14





E-mail ID :sepwddelhicnd@gmail.com

#### Superintending Engineer

Central & New Delhi Circle
Public Works Department
Govt. of NCT of Delhi,
Bhairon Road T-Junction, Ring Road,
Near Pragati Power Station,
New Delhi-110002

Phone No.: 23378613 / 14

Date: 03-05-2018

# Inspection Note

No. 23(15)/SE/C&ND/PWD/2018-19/ / 805

Inspection of Road around NCAER Building, Ring Road Bypass etc. were carried out on 25.04.2018 along with Sh. Yadwinder Singh, EE (C&ND Road) and Sh. Vinod Garg, AE (C&ND Road). During the inspection, following directions were given:-

A) Service Road along NCAER Building – Repair to footpath towards NCAER Building is in progress. Existing footpath of on the other side should also be repaired by providing tiles/concrete. Drain should also be repaired and manhole cover should be placed at the level of footpath.

# B) Ring Road Bypass -

- 1) Damaged brick work at central verge may be repaired and painted.
- 2) Damaged metallic crash barrier should be repaired.
- 3) In the plaster, self curing compound may be used.

## C) Misc. Issues -

- 1) Additional signboard as suggested by Traffic Police may be provided.
- Chevron near Mangi Bridge while coming from Ring Road Bypass may be provided.
- 3) Orange colour bollards may be provided near Mangi Bridge and Vidhan Sabha.
- 4) Flexible medium marker may be provided on Ring Road from Metcalfe House to Timarpur X-ing.

प्रतिलिपि प्रेषित:-

- 1. The Pr. CE (M), PWD, 12th Floor, MSO Building, New Delhi-110002.
- 2. The EE, C&ND (M-413), PWD, Bhairon Road T-Jn., Ring Road, New Delhi-110002.
- 3. The EE, (DHC/ND) Elect. Divn. (M-451), PWD, Ground Floor, MSO Bldg., Delhi-110002.
- The DDH Divn. (M-214), PWD, G.S. Mihar Bhoaj Vatika, NH-24, Nizamuddin Bridge, New Delhi-110091.
- 5. Guard file.

व अधीक्षण अभियन्ता