



सत्यमेव जयते

राष्ट्रीय राजधानी क्षेत्र दिल्ली सरकार
GOVT. OF NATIONAL CAPITAL TERRITORY OF DELHI
लोक निर्माण विभाग
PUBLIC WORKS DEPARTMENT
e-mail: pmpwddelhihealth2@gmail.com



अधीक्षण अभियंता
स्वास्थ्य सिविल परिमंडल-II
लो०नि०वि०, दिल्ली सरकार,
डा० बी०एस०ए० अस्पताल परिसर,
सैक्टर-6, रोहिणी, नई दिल्ली-110085
दूरभाष: 011-23490290 फैक्स : 011-23715082

SUPERINTENDING ENGINEER
HEALTH CIRCLE (CIVIL)-II,
PWD, Govt. of NCT Delhi,
Dr. B.S.A. HOSPITAL COMPLEX,
SECTOR-6, ROHINI, NEW DELHI - 110085
Ph: 011-23490290 Fax : 011-23715082

No.: 23(misc)/SE(C)H-III//PWD/2018-19/ 47

Dated: 12-3-2019

INSPECTION NOTE

The site of the polyclinic at Rohini (Sector-21), Sultanpuri and Mangolpuri were inspected on 11/03/2019. The work is in the initial stage and the following shall be observed:

- 1) The template shall be used for fixing of Anchor bolts in foundation, so that proper fixing in line and plumb is maintained.
- 2) It shall be ensured that the base plate of steel columns have proper oval shaped holes for proper fixing at designated line and length.
- 3) The base plate shall be fixed over columns with gap that shall be filled with anti shrink grout.
- 4) There shall not be any loose pocket in the makeup slab and the continuity shall be maintained.
- 5) The new construction is the extension of old building and as such the special care shall be taken to maintain the levels.
- 6) The proper arrangements shall be made for ingress and egress of patients visiting the dispensary as they have to pass through the construction area.
- 7) The condition of the old building of dispensary at Sultanpuri is not good. The plaster / cover portion of RCC beam has cracked and spalling is in progress. The rehabilitation of RCC beams and columns shall be done before the repairing / finishing work.
- 8) The contractor shall be asked to submit he revised programme for completion of work.

- 9) The major samples shall be got approved from this office as directed under Clause 53.7(i) of CPWD Works Manual 2014.
- 10) The contractor shall be asked to submit the progress report as per the Clause 5.1(v) of General Conditions of Contract of CPWD works appended with the agreement.

(आर० के० मल्हौत्रा)

अधीक्षण अभियंता (सि०), स्वास्थ्य परि०-॥

प्रतिलिपि:

1. मुख्य अभियंता, स्वा० अनुरक्षण अंचल, लो०नि०वि०, 2 तल, बहुमंजिला भवन, नई दिल्ली को सूचनार्थ हेतू प्रेषित।
2. कार्यपालक अभियंता, स्वा० अनु० मंडल-उत्तर, लो०नि०वि०, नई दिल्ली।

अधीक्षण अभियंता (सि०), स्वास्थ्य परि०-॥