

राष्ट्रीय राजधानी क्षेत्र दिल्ली सरकार

GOVT. OF NATIONAL CAPITAL TERRITORY OF DELHI

कार्यालय अधीक्षण अभियन्ता
लो.नि.वि. अनुरक्षण परिमंडल (पूर्व)
दिल्ली सचिवालय, दूसरा तल, सी-218, नई दिल्ली 110002
दूरभाष: 011-23392194, फ़ैक्स: 011-23392191



Office of Superintending Engineer
PWD Maintenance Circle (East)
Delhi Secretariat, 2nd Level, C-218,
IP Estate, New Delhi-110 002.
E-mail: sepwddelhim22@gmail.com

सं. 23(QC)/लो0नि0वि0/अनु0परि0(पूर्व)/ 2769

दिनांक: 23.12.2019

विषय:- Issuance of Fire safety certificate in r/o Delhi Secretariat Building.

संदर्भ:- इस कार्यालय का कार्यालय आदेश सं. 54(Misc.)/लो0नि0वि0/अनु0परि0 (पूर्व)/2744 दिनांक 20.12.2019.

In reference to above, Delhi Sachivalaya Building was inspected by the undersigned alongwith Executive Engineer (E), Executive Engineer (C) and GAD Officials on 23.12.2019 to assess the action taken by the different units on the observations issued by Chief Fire Officer, Delhi vide his office letter No. F.6/DFS/MS/2019/6459 dt. 28.10.2019 and following was observed:-

1. Common places at Ground Floor and Fire Exit are still blocked by placing Civil bldg. Material and electrical materials. In Yoga Hall / MP Hall, lot of e-waste has been dumped by the GAD Deptt. It has been directed to all the concerned that all such materials should be removed from the site by 27.12.2019 in all respect.
2. Pump room near underground tank was also inspected. The fire pumps are not operable on auto-mode during pressure drop of water and lot of other material was lying which is fire hazard. EE (E) to take immediate measures on this account.
3. Lot of dismantle material of the GAD Deptt. was lying in front of the Pump room and dismantled building material in front of Entry Gate No. 7. EE (C) and GAD Officials may take immediate action for removal of dismantle material.
4. Office furniture has been placed on the way of fire exit doors at different locations / floors of Sachivalaya building. GAD should take immediate action to remove all such items for free access to the fire exit doors.
5. EE (E) may ensure that fire tank at roof of the building should be in functional condition.
6. EE (E) told that other observations have been complied with necessary smoke detecting test will be done on Saturday.

Executive Engineer (E), Executive Engineer (C) and GAD Officials will submit the action taken report on 30.12.2019 positively, so that the Chief Fire Officer, Delhi may be invited for inspection of the Delhi Sachivalaya Building for obtaining Fire Safety Certificate.

This may be given **top priority**.

अधीक्षण अभियन्ता (पूर्व) एम

प्रतिलिपि:-

1. सचिव, सामान्य प्रशासन विभाग, दि.स., द्वितीय तल, ए-विंग, दिल्ली सचिवालय, नई दिल्ली को सूचनार्थ।
2. प्रधान मुख्य अभियन्ता (अनुरक्षण एवं फ्लाइओवर), लोनिवि, बारहवां तल, एम.एस.ओ. भवन, नई दिल्ली को सूचनार्थ।
3. उप-सचिव, सामान्य प्रशासन विभाग, दि.स., द्वितीय तल, ए-विंग, दिल्ली सचिवालय, नई दिल्ली को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
4. कार्यपालक अभियन्ता, लो.नि.वि. भवन अनु0 मं0 (पूर्व)/एम 221, दिल्ली सचिवालय, नई दिल्ली को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
5. कार्यपालक अभियन्ता (वै0), लो.नि.वि. वैद्युत अनु0 मं0 (पूर्व)/एम 253, दिल्ली सचिवालय, नई दिल्ली को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
6. वेबसाइट WIMS.
7. गार्ड फाइल।

अधीक्षण अभियन्ता (पूर्व) एम