

राष्ट्रीय राजधानी क्षेत्र दिल्ली सरकार

GOVT. OF NATIONAL CAPITAL TERRITORY OF DELHI

कार्यालय अधीक्षण अभियन्ता  
लो.नि.वि. अनुरक्षण परिमंडल (पूर्व)  
दिल्ली सचिवालय, दूसरा तल, सी-218, नई दिल्ली 110002  
दूरभाष: 011-23392194, फैक्स: 011-23392191



Office of Superintending Engineer  
PWD Maintenance Circle (East)  
Delhi Secretariat, 2<sup>nd</sup> Level, C-218,  
IP Estate, New Delhi-110 002.  
E-mail: [sepwddelhim22@gmail.com](mailto:sepwddelhim22@gmail.com)

सं 23(निरिक्षण)/लोनिवि/अनुपरि (पूर्व) / 693

दिनांक: 18.06.2020

**कार्य:- Inspection in respect of working of sewer pumps under jurisdiction of North-East Circle.**

In reference to the office order issued by Dy. Director-I, O/o Pr. CE (M), PWD vide No. 23(37)/Pr. CE(M)/PWD/2020/1130 dt. 15.06.2020, the pumping stations of North-East Circle were inspected by SE (East)M on 17.06.2020 at 10:00 AM. The following were present.

**PWD**

1. Sh. S.K. Dey AE (Elect.), M-2511
2. Sh. C.L. Meena JE (Elect.) M-2511

The status report is as under:

S. No.	Location	DG Set	Maintained by Agency with Mob. No.	Capacity of Pumps	Qty. of Pumps	Status of Pumps (working or not)
1	Harsh Vihar	250 KVA ( Greaves) -1 Nos Working)	M/S A.K. Electric Work (9990990239)	75 HP	1	Working
				150 HP	1	Not Working
				100 HP	4	3 Nos Working 1 Nos not Working
2	Dividing Road Yamuna Vihar	250 KVA (Greaves) -1 Nos Working	M/S A.K. Electric Work (9990990239)	75 HP	3	Working
				40 HP	1	Working
				30 HP	1	Working
				100 HP	2	Working
3	S.B.S Yamuna Vihar	200 KVA (Kirloskar)- 1 Nos (Not Working)	M/S A.K. Electric Work (9990990239)	100 HP	1	Not Working
				150 HP	1	Not Working
				75 HP	4	3 Nos Working 1 No. Not Working
4	MIG flat Ioni Road	250 KVA (Greaves) -1 Nos and 250 KVA (Kirloskar) -1 No (Not Working)	M/S A.K. Electric Work (9990990239)	150 HP	1	Not Working
				75 HP	3	2 No. Working 1 Nos not Working
				100 HP	3	2 Nos Working 1 No. Not Working
5	Gokul Puri	DG Set not available	M/S A.K. Electric Work (9990990239)	75 HP	1	Working
				submersible 20 HP	2	2 Nos Not Working

