



सत्यमेव जयते

राष्ट्रीय राजधानी क्षेत्र दिल्ली सरकार  
GOVT. OF NATIONAL CAPITAL TERRITORY OF DELHI  
लोक निर्माण विभाग  
PUBLIC WORKS DEPARTMENT  
e-mail: pmpwddelhihealth2@gmail.com



अधीक्षण अभियंता  
स्वास्थ्य सिविल परिमंडल-II  
लो०नि०वि०, दिल्ली सरकार,  
डा० बी०एस०ए० अस्पताल परिसर,  
सैक्टर-6, रोहिणी, नई दिल्ली-110085  
दूरभाषः:011-27933378, 27933240

SUPERINTENDING ENGINEER  
HEALTH CIVIL CIRCLE -II,  
PWD, GOVT. of NCT DELHI,  
DR. B.S.A. HOSPITAL COMPLEX,  
SECTOR-6, ROHINI, NEW DELHI - 110085  
PHONE: 011-27933378, 27933240

संख्या.: 23(निरीक्षण)/अधी०अभि०स्वा०-II//लो०नि०वि०/2020-21/ 187H

दिनांक: 27-01-2021

### INSPECTION NOTE

**Name of work: C/o New Hospital at Siraspur, Delhi.**

The subject work was inspected on 27/01/2021 by the undersigned and the following has been observed and corrective action shall be taken:

1. The work of laying of reinforcement for raft foundation is in progress. The laying is to be completed in 04 days. It shall be ensured that the cover blocks are placed properly.
2. The side reinforcement in lift pit no. 2 was more than 75 mm beyond the water proofing edge. The reinforcement cage shall be pushed back for proper cover.
3. The excavated sandy soil shall be retained for filling in the foundation. The surplus sand shall not be disposed off.
4. During the discussions with the Project Manager, it was informed that the aluminium shuttering for columns is being prepared. It shall be ensured that the shuttering have adequate arrangement of windows in shuttering to cast the columns in lifts.
5. The design of pedestrian over bridge connecting the building with bridge on the road shall be finalised as the foundation of same may be falling in the area that has been excavated for keeping side slopes of raft of main block.
6. The methodology of casting raft foundation in continuity may be submitted before start of work. In case of construction joints, its due location shall be finalised by the consultant and the chemicals to be used to maintain the joint at old and new concrete point shall be procured.
7. The due care shall be taken before start of work to procure all the materials required for concreting due to ongoing farmer's agitations nearby.

( आर० के० मल्हौत्रा )

अधीक्षण अभियंता (सि०), स्वास्थ्य परि०-II

P.T.O.

प्रतिलिपि:

- 1- मुख्य अभि० स्वा० अंचल, लो०नि०वि०, 2रा तल, बहुमंजिला भवन, नई दिल्ली को सूचनार्थ हेतू प्रेषित।
- 2- अधीक्षण अभियंता (वैद्युत), स्वास्थ्य वैद्युत परिमंडल, 2रा तल, एम०एस०ओ० भवन, आई०पी० इस्टेट, नई दिल्ली-110002
- 3- कार्यपालक अभियंता (सिविल), स्वास्थ्य परि० मंडल (उत्तर), लो०नि०वि०, नई दिल्ली।
- 4- कार्यपालक अभियंता (वै०), स्वा०वै०म०-उत्तर, लो०नि०वि०, डा० बी०एस०ए० अस्पताल, दिल्ली-110085
- 5- मै० रामा सिविल इंडिया कन्सट्रक्शन प्रा० लिमिटेड, एच-240, अशोक विहार, फेस-1, दिल्ली-110052
- 6- फाइल संख्या 23(7)

अधीक्षण अभियंता (सि०), स्वास्थ्य परि०-II