



राष्ट्रीय राजधानी क्षेत्र,
दिल्ली सरकार
लोक निर्माण विभाग
अधीक्षण अभियंता
फ्लाईओवर-5

Govt. of NCT of Delhi

Public Works Department
Superintending Engineer
Flyover- 5



रिंग रोड फ्लाईओवर के नीचे, विपरीत आई0 जी0 स्टेडियम गेट नं0 9, नई दिल्ली-110002

Under Ring Road Bypass Flyover, Opp. of IG Stadium Gate No.9, New Delhi-110002

Email: cpmpwddelhif5@gmail.com

No. 23(Insp.)/PWD/SE/F-5/2023/102

dated /4 .08.2023

निरीक्षण नोट

A site inspection was done by undersigned at 11:00 AM on 08.03.2023 for the work "Flyover at Nand Nagri & Gagan Cinema Junction of Mangal Pandey Marg".

- PWD Side:**
1. Sh. Ajay Narwal , E.E., F-31) - Additional Charge
 2. Sh. Surjeet Kumar, Asstt. Engineer, F-312
 3. Sh. Dinesh Kumar, Asstt. Engineer, F311
- Agency Side:**
1. Sh. Krishan Goyal (Managing Director)
 2. Sh. Sitaram Vats (Deputy Project Manager)

During the inspection, the following has been observed: -

1. Progress of work was reviewed, it was appraised that Piling, Pile Cap & Pier Cap work in progress. Agency was asked to improve the pace of work and directed to match the progress as enumerated in work programme. **(Action: - Agency, EE, AE)**
2. Agency was asked to give pictorial representation to the progress of work. **(Action: - Agency, EE, AE)**
3. Construction malba should be removed from site as per terms & Condition of agreement. **(Action: - Agency, EE, AE)**
4. Date of casting should be marked after removal of shuttering to monitor the curing. Potholes should be filled on urgent basis. **(Action: - Agency, EE, AE)**
5. **Safety issues:-** Reflective tape to be provided for smooth movement of traffic. Workers & Engineer deployed at site should be with all safety equipment. Appropriate lighting arrangement should be provided for smooth movement of traffic during night period. At all active site location should be barricaded properly to avoid any accident at site. Sufficient Marshalls should be deployed at junction around moving machinery/ equipment for safe movement of road users. **(Action: - Agency, EE, AE)**