



लोक निर्माण विभाग
अधीक्षण अभियंता

फ्लाईओवर-5

रिंग रोड फ्लाईओवर के नीचे, विपरीत आई0 जी0 स्टेडियम गेट नं0 9, नई दिल्ली-110002
Under Ring Road Bypass Flyover, Opp. of IG Stadium Gate No.9, New Delhi-110002

Public Works Department
Superintending Engineer
Flyover- 5



Email: cpmpwddelhi5@gmail.com

No. 23(Insp.)/PWD/SE/F-5/2023/159

Dated 26.08.2023

निरीक्षण नोट

A site inspection was done by undersigned at 11:00 AM on ²⁶08.08.2023 for the work 'Flyover at Nand Negri & Gagan Cinema Junction of Mangal Pandey Marg'.

PWD Side: 1 Sh. Ajay Narwal E.E.. F-31) - Additional Charge

2. Sh. Surjeet Kumar, Asstt. Engineer, F-312

3. Sh. Dinesh Kumar, Asstt. Engineer, F311

Agency Side: 1. Sh. Kristian Goyal (Managing Director)

2. Sh. Sitaram Vats (Deputy Project Manager)

During the inspection, the following has been observed: -

1. Progress of work was reviewed, it was appraised that Piling, Pile Cap & Pier Cap work in progress. Agency was asked to improve the pace of work and directed to match the progress as enumerated in work programme. **(Action: - Agency, EE, AE)**
2. The Casting yard and plant site was visited, lab area and various registers were reviewed and it was directed to do all testing and to be recorded as per QAP plan and shall be produced for perusal from next visits onwards. **(Action: - Agency, EE, AE)**
3. Safety issues:- Reflective tape to be provided for smooth movement of traffic. Workers & Engineer deployed at site should be with all safety equipment. Appropriate lighting arrangement should be provided for smooth movement of traffic during night period. At all active site location should be barricaded properly to avoid any accident at site. Sufficient Marshalls should be deployed at junction around moving machinery/equipment for safe movement of road users. **(Action: - Agency, EE, AE)**
4. Agency was also asked to provide the marshals/arrangement as per agreement provision for smooth movement of pedestrians and vehicle at junctions and crossing point. **(Action: - Agency, EE, AE)**
5. It was also pointed out that suitable dust mitigation measures shall be taken as per agreement provisions. **(Action: - Agency, EE, AE)**
6. Agency to adhere to all safety guidelines as per agreement, CPWD Works Manual Safety codes, Good structural engineering practices & as issued by GNOTO,;*10.No. 4(60)/23-24/PWD-II/Roads (CD No 057742583)11054-47 dated 11.0,a Responsibility of any violation shall be of executing agency & EE should take action as per guidelines for any violation. **(Action:- Agency,EE, AE)**

का.प्र.पू.रि.

26-8-23
रिजिन मोघा)
अधीक्षण अभियंता

प्रतिलिपि सूचनार्थ प्रेषित-

1. मुख्य अभियंता, (फलाईओवर), लोक निर्माण विभाग, एम0एस0ओ0बिल्डिंग, नई दिल्ली को सूचनार्थ।
2. कार्यपालक अभियन्ता, एफ-31, गेट नं. 06, जवाहरलाल नेहरु, स्टेडियम नई दिल्ली को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
3. सहायक अभियन्ता, लोक निर्माण विभाग, को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
4. मैसर्स राम कुमार, कांटेक्टर प्राईवेट लिमिटेड, एस.सी.एफ-60, पहला तल सेक्टर -8, पंचकूला -134109।

कार्य प्रती
अधीक्षण अभियंता