



राष्ट्रीय राजधानी क्षेत्र, दिल्ली सरकार
लोक निर्माण विभाग
अधीक्षण अभियंता
फ्लाईओवर-5

Govt. of NCT of Delhi
Public Works Department
Superintending Engineer
Flyover- 5



रिंग रोड फ्लाईओवर के नीचे, विपरीत आई० जी० स्टेडियम गेट न० ९, नई दिल्ली-110002
Under Ring Road Bypass Flyover, Opp. of IG Stadium Gate No.9, New Delhi-110002

Email: cpmpwddelhi5@gmail.com

No. 23(Insp.)/PWD/SE/F-5/2023/ 171

Dated 29 .08.2023

निरीक्षण नोट

Name of work: Construction of flyover with Ramps, Footpath, Road work including Road Signage, Street Lights works, Drainage, Horticulture, Mural works 7 allied work at Road No. 56 between Anand Vihar ROB, and Apsara border ROB, New Delhi (EPC Mode).

Agreement No.- 02/EE/F-51/PWD/2022-23

Agency:- M/s. GAWAR CONSTRUCTION LIMITED

The inspection of the above work was carried out by the undersigned on dated 25.08.23 in presence of following-

PWD Side: Sh. Rajesh Kumar Gupta, Executive Engineer, F-51

Sh. Sheikh Nizam, Assistant Engineer, F- 513

Agency Side: Shri Gaurav Ahalawat, Agency Representative

Shri Praveen Kaushik, Deputy Project Manager

During the inspection the following points were discussed:-

1. Retaining wall & hump subway work is not carried out in full swing. Agency may take necessary step to complete the work within stipulated time period, as per inspection note issued by this office vide No.23(MN)/PWD/SE/F-5/2023/65 dated 04.08.2023 earlier decided.

(Action :- Agency ,EE,AE)

2. **Safety issues:-** Reflective tape to be provided at required location for safety of road users .Worker and Engineer deployed at site should be with all safety equipment. Appropriate lighting arrangement should be provided for smooth movement of traffic during night period. Sufficient Marshall should be deployed at junction & around moving machinery / equipment for safe movement of road users. Loose shuttering plate, reinforcement bars & staging creeps needs to be removed from carriageway.

(Action :- Agency ,EE,AE)

3. Cleaning of carriageway and water sprinkling should be carried out on daily basis to facilitate the road users & for pollution Control of site.

(Action :- Agency ,EE,AE)

4. Site information signage is not fixed yet. Agency may take necessary action.

(Action :- Agency ,EE,AE)

5. Retaining wall work in drain may please be started at site as laying of BSES Cabling work maybe started.

(Action :- Agency ,EE,AE)

6. Agency to adhere to all safety guidelines as per agreement, CPWD Works Manual, Safety codes, Good structural engineering practices & as issued by GNCTD vide No. 4(60)/23-24/PWD-II/Roads (CD No. 057742583)/1054-47 dated 11.07.2023. Responsibility of any violation shall be executing agency & EE should take action as per guidelines for any violation. (Action :- Agency, EE, AE)

(Action :- Agency ,EE,AE)

OK
(रजनी मोघा)
अधीक्षण अभियंता

प्रतिलिपि सूचनार्थ प्रेषित:-

1. मुख्य अभियन्ता (फलाईओवर), लो.नि.वि., चौथा तल, एम.एस.ओ.भवन, नई दिल्ली।
2. कार्यपालक अभियन्ता, एफ-51, रिग रोड फलाईओवर के नीचे, विपरीत आई.जी.आई. स्टेडियम गेट नं. 09, नई दिल्ली को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
3. सहायक अभियन्ता, एफ-513, लोक निर्माण विभाग, नई दिल्ली को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
4. मैसर्स गावर कंस्ट्रक्शन लिमिटेड, डी.डी.स-378, सेक्टर 16-17, हिसार-125005 (हरियाणा) को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।

OK
अधीक्षण अभियंता