



राष्ट्रीय राजधानी क्षेत्र, दिल्ली सरकार  
लोक निर्माण विभाग  
अधीक्षण अभियंता  
फलाईओवर-5

Govt. of NCT of Delhi  
Public Works Department  
Superintending Engineer  
Flyover- 5



रिंग रोड फलाईओवर के नीचे, विपरीत आई0 जी0 स्टेडियम गेट नं0 9, नई दिल्ली-110002  
Under Ring Road Bypass Flyover, Opp. of IG Stadium Gate No.9, New Delhi-110002

Email: cpmpwddelhi5@gmail.com

सं0 23(10)/अधी.अभि./एफ-5/लो.नि.वि./2023-24/200

दिनांक 28/02/2024

### निरीक्षण नोट

कार्य का नाम: Construction of flyover with Ramps, Footpath, Road work including Road Signage, Street Lights works, Drainage, Horticulture, Mural works 7 allied work at Road No. 56 between Anand Vihar ROB, and Apsara border ROB, New Delhi (EPC Mode).

करार संख्या- 02/EE/F-51/PWD/2022-23

एजेंसी:- M/s. GAWAR CONSTRUCTION LIMITED

The inspection of the above work was carried out by the undersigned on dated 27.02.2024 in presence of following:-

**PWD Side:** Sh. Ajay Narwal, Executive Engineer, F-51  
Sh. Sheikh Nizam, Assistant Engineer, F- 513

**Agency Side:** Shri Praveen Kaushik, Deputy Project Manager

During the inspection the following points were discussed :-

1. During inspection of site, it is found that 2 Nos. static anti-smog gun deployed at site but not found in running. Agency may ensure for running of same round the clock at proper interval of time for dust supervision.
2. Cleaning of carriageway and water sprinkling should be carried out on daily basis to facilitate round users & pollution control of site.
3. Reflective tape to be provided at required location for safety of road users. Worker and Engineer deployed at site should be with all safety equipment. Appropriate lighting arrangement should be provided for smooth movement of traffic during night period.
4. Agency may provide appropriate safety of trees available at site till receiving of NOC from forest department.
5. Agency to adhere to all safety guidelines as per agreement, CPWD Works Manual, Safety codes, Good structural engineering practices & as issued by GNCTD vide No. 4(60)/23-24/PWD-II/Roads (CD No. 057742583)/1054-47 dated 11.07.2023. Responsibility of any violation shall be executing agency & EE should take action as per guidelines for any violation. (Action:- Agency, EE, AE).

012


28-2-24

अधीक्षण अभियंता,  
फलाईओवर परियोजना परिमण्डल एफ-5

प्रतिलिपि सूचनार्थ प्रेषित:-

1. मुख्य अभियन्ता (पलाईओवर), लो.नि.वि., चौथा तल, एम.एस.ओ.भवन, नई दिल्ली।
2. कार्यपालक अभियन्ता, एफ-51, रिंग रोड पलाईओवर के नीचे, विपरीत आई.जी.आई. स्टेडियम गेट नं. 09, नई दिल्ली को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
3. कार्यपालक अभियन्ता (विधुत), एफ-13, लो.नि.वि.(दि.स.), मुकरया चौक, जी.टी. करनाल रोड नई दिल्ली को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
4. सहायक अभियन्ता, एफ-513, लोक निर्माण विभाग, नई दिल्ली को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
5. मैसर्स गावर कंस्ट्रक्शन लिमिटेड, डी.डी.स-378, सेक्टर 16-17, हिसार-125005 (हरियाणा) को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।

01/

  
अधीक्षक अभियन्ता