



राष्ट्रीय राजधानी क्षेत्र, दिल्ली सरकार  
लोक निर्माण विभाग  
अधीक्षण अभियंता  
पलार्डओवर-5

रिंग रोड पलार्डओवर के नीचे, विपरीत आई0 जी0 स्टेडियम गेट नं0 9, नई दिल्ली-110002  
Under Ring Road Bypass Flyover, Opp. of IG Stadium Gate No.9, New Delhi-110002

Email: [cpmpwddelhi5@gmail.com](mailto:cpmpwddelhi5@gmail.com)

Govt. of NCT of Delhi  
Public Works Department  
Superintending Engineer  
Flyover- 5



सं0 23(10)/अधी.अभि./एफ-5/लो.नि.वि./2023-24/745(H)

दिनांक 09/09/2024

### निरीक्षण नोट

कार्य का नाम: :- Construction of Flyover with Ramps, Footpath, Road Work including Road Signage, Street Light works, Drainage, Horticulture, Mural Works & allied works at Road No. 56 between Anand Vihar ROB and Apsara Border ROB, New Delhi (EPC Mode).

एजेंसी:	M/s Gawar Construction Ltd.
करार संख्या:	02/EE/F-51/PWD/2022-23
निविदा लागत:	257.34 Cr.
आरंभ की तिथि (अनुबद्ध)	10.09.2022
समापन की तिथि (वास्तविक)	08.12.2023
प्रगति:	98%

Inspection of above work was carried out by the undersigned on 03.09.2024 along with below PWD official & agency representative.

#### **PWD Side:**

1. Sh. Rajan Mogha	Superintending Engineer, F-5
2. Sh. Anil Kumar Yadav	Executive Engineer, F-51
3. Sh. S. K. Tayal	Executive Engineer, F-13
4. Sh. Sheikh Nizam	Assistant Engineer, F-513


#### **Agency Side:**

1. Sh. Gaurav Ahlawat	Agency Representative
2. Sh. Umar Iqbal	Agency Representative

#### **During Inspection of the point discussed given below:-**


1. Take down pipe & spout fixed for drainage found leaking at few locations. Agency to take necessary action for rectification.
2. Balance work of Hump subway & widening of side up & down ramp adjacent to A1 ramp is to be expedited for timely completion of work.

3. Rainwater harvesting design & drawing to be submitted by agency.
4. Balance work for drainage & footpath, NMT should be expedite.
5. **Proper diversion arrangement should be fixed around available tree at down ramp with spring posts, reflective diversion, rumble strips & cautionary signage for safety of road users. Agency and EE to submit a drawing for approval.**
6. Balance work of electrical fitting, fixture and electricity connection should be expedited.
7. For opening of traffic with available hindrance of trees on down ramp necessary comments may be obtained from Delhi traffic police.
8. Agency may provide appropriate safety of trees available at site till receiving of NOC from forest department.
9. Agency to adhere to all safety guidelines as per agreement, CPWD Works Manual, Safety codes, Good structural engineering practices & as issued by GNCTD vide No. 4(60)/23-24/PWD-II/Roads dated 11.07.2023. Responsibility of any violation shall be executing agency & EE should take action as per guidelines for any violation

  
 ओक अधीक्षण अभियंता,  
 फलाईओवर परियोजना परिमण्डल एफ-5

प्रतिलिपि सूचनार्थ प्रेषित:-

1. प्रमुख अभियन्ता, लो.नि.वि., 12वां तल, एम.एस.ओ.भवन, नई दिल्ली-110002।
2. प्रधान मुख्य अभियंता,(अनुरक्षण एवं फलाईओवर) लोक निर्माण विभाग, 12वां तल,एम0एस0ओ0बिल्डिंग, नई दिल्ली।
3. मुख्य अभियन्ता (फलाईओवर), लो.नि.वि., चौथा तल, एम.एस.ओ.भवन, नई दिल्ली।
4. कार्यपालक अभियन्ता, एफ-51, रिंग रोड फलाईओवर के नीचे, विपरीत आई.जी.आई. स्टेडियम गेट नं. 09, नई दिल्ली को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
5. कार्यपालक अभियंता (विद्युत), एफ-13, लो.नि.वि.(दि.स.), मुकरबा चौक, जी.टी. करनाल रोड नई दिल्ली को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।
6. मैसर्स गावर कंस्ट्रक्शन लिमिटेड, डी.डी.स-378, सेक्टर 16-17, हिसार-125005 (हरियाणा) को सूचनार्थ एवं आवश्यक कार्यवाही हेतु।

  
 ओक अधीक्षण अभियंता